

June 26, 1985

Docket No. 50-344

Mr. Bart D. Withers  
Vice President - Nuclear  
Portland General Electric Company  
121 S. W. Salmon Street  
Portland, Oregon 97204

Dear Mr. Withers:

SUBJECT: GENERIC LETTER 83-28, ITEM 1.1 POST-TRIP REVIEW

The staff is continuing its review and evaluation of PGE's responses to Generic Letter 83-28 with regard to required actions based on generic implications of the SALEM ATWS events. Enclosure 1 is the staff's Safety Evaluation (SE) of the appropriate portions of your November 4, 1983 submittal concerning Item 1.1 of Generic Letter 83-28, Post-Trip Review.

During our review, the staff found that your post-trip review program did not provide for an independent assessment of the event following a trip. It is the staff's position that, if any of the restart criteria as presented in Section II.A of the enclosed SE are not met, an independent assessment of the event should be performed.

Based on our review, we concluded that, subject to successful resolution of the above cited deficiency, your Post-Trip Review Program and Procedures for Trojan Nuclear Plant are acceptable. The staff requests that you provide the additional information necessary to resolve this matter within 30 days of receipt of this letter or provide a date that you can meet within 15 days of your receipt of this letter.

We are available to meet with your staff, if needed, to discuss our concern. Should you have any questions or wish to arrange such a meeting, please contact the Project Manager, Lisamarie Lazo, at 301 492-7791.

The information requested in this letter affects fewer than 10 respondents; therefore, OMB clearance is not required under P. L. 96-511.

Sincerely,

Edward J. Butcher, Acting Chief  
Operating Reactors Branch No. 3  
Division of Licensing

Enclosure:  
Safety Evaluation

cc w/enclosure:

ORB#3:DLW  
PKreutzer

6/24/85

ORB#3:DL  
LLazo:ef  
/ /85

ACRS 10  
NRC & L PDRs  
**Docket File**  
PKreutzer

Branch Files 1+1  
OELD  
HThompson  
LLazo

EButcher  
PMcKee  
EJordan  
BGrimes

ORB#3:DL  
EButcher  
6/24/85

B507090156 B50626  
PDR ADOCK 05000344  
P PDR

Mr. Bart D. Withers  
Portland General Electric Company

Trojan Nuclear Plant

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Trojan Nuclear Plant  
Post Office Box 0  
Rainier, Oregon 97048

Robert M. Hunt, Chairman  
Board of County Commissioners  
Columbia County  
St. Helens, Oregon 97501

William T. Dixon  
Oregon Department of Energy  
Labor and Industries Building  
Room 111  
Salem, Oregon 97310

Regional Administrator  
USNRC, Region V  
Office of Executive Director for Operations  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596