



**GPU Nuclear Corporation**  
100 Interpace Parkway  
Parsippany, New Jersey 07054-1149  
(201) 263-6500  
TELEX 136-482  
Writer's Direct Dial Number:

May 9, 1985

Mr. Thomas T. Martin, Director  
Division of Engineering and  
Technical Programs  
U.S. Nuclear Regulatory Commission  
King of Prussia, Pa. 19406

Dear Mr. Martin:

Subject: Oyster Creek Nuclear Generating Station  
Docket No. 50-219  
Inspection No. 50-219/84-31

The following is provided in response to your letter of January 17, 1985 concerning the subject matter.

With respect to Equipment Classification, GPUN presently has provisions in place to identify the safety classification of major systems, components and structures at the plant as well as provisions for controlling safety-related activities associated with these items. The recently established Engineering Assurance group has been assigned the responsibility of developing a component level Quality Classification List (QCL) and it is our intent to respond to this issue by the end of the 3rd quarter of 1985.

With respect to Vendor Interface, GPUN intends to provide this information by the end of the 2nd quarter of 1985 as conveyed to Mr. Epan during the course of this inspection.


With respect to Post-Maintenance Testing, GPUN is currently developing a Post-Maintenance Testing Program which addresses the concerns of Generic Letter 83-28. The key elements consist of:

8505300457 850509  
PDR ADDCK 05000219  
Q PDR

1. Identification of the appropriate QCL components.
2. Development of administrative plant procedures to define a program for the preparation, use, maintenance and control of the Post-Maintenance Testing data base.
3. Identification of the appropriate vendor and engineering test guidance.
4. Development of generic Post-Maintenance Testing requirements and guidelines for their use.
5. Review of existing plant procedures relative to the generic Post-Maintenance Testing requirements and INPO Good Practices.

The implementation of the program will be phased based upon availability of the various elements. The administrative procedure shall be in place prior to the Cycle 11 Refueling Outage which will implement the first phase. The remaining phases, in order to be considered complete, are dependent upon the final completion of such items as our vendor interface program and the development of the QCL list.

Very truly yours,



P. B. Fiedler  
Vice President and Director  
Oyster Creek

1r/1670f

cc: Dr. Thomas E. Murley, Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pa. 19406

NRC Resident Inspector  
Oyster Creek Nuclear Generating Station  
Forked River, N. J. 08731

J. Donohew  
U.S. Nuclear Regulatory Commission  
7920 Norfolk Avenue  
Bethesda, Maryland 20014