

July 1, 1985

Docket Nos. 50-325/324

Mr. E. E. Utley
Executive Vice President
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Dear Mr. Utley:

SUBJECT: RESPONSE TO GENERIC LETTER 84-11 RE
STAINLESS STEEL PIPING REINSPECTION

Re: Brunswick Steam Electric Plant, Units 1 and 2

By letters dated June 1, and June 14, 1984, you submitted a response to Generic Letter 84-11. In the letters you indicated that reinspections of intergranular stress corrosion cracking (IGSCC) susceptible piping welds will be performed during the Brunswick Unit 1 refueling outage in 1985 and the Brunswick Unit 2 refueling outage in 1986, with the sample chosen in accordance with the criteria provided in Generic Letter 84-11 and using qualified (ultrasonic testing) UT personnel with capabilities demonstrated in accordance with IE Bulletin 83-02 and Generic Letter 84-11. You also stated that the special coolant leakage surveillance measures already implemented at the Brunswick plant and the remedial measures to be taken when cracks are discovered are consistent with those given in Attachments 1 and 2 to Generic Letter 84-11, respectively. Based on the above and our review of your letters, we conclude that Carolina Power & Light Company's (CP&L) piping inspection plan meets the guidelines in Generic Letter 84-11.

Sincerely,

Original signed by MGrotenhuis for/

Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

cc: See next page

DISTRIBUTION

Docket File

NRC PDR

Local PDR

ORB#2 Reading

HThompson

OELD

SNorris

MGrotenhuis

ELJordan

JPartlow

BGrimes

ACRS (10)

Gray File

WKoo

WVJohnston

DL:ORB#2

SNorris:ajs

706/1/85

DL:ORB#2

MGrotenhuis

06/1/85

DL:ORB#2

DVassallo

06/1/85

8507090466 850701
PDR ADOCK 05000324
PDR

Mr. E. E. Utley
Carolina Power & Light Company
Brunswick Steam Electric Plant, Units 1 and 2

cc:

Richard E. Jones, Esquire
Carolina Power & Light Company
336 Fayetteville Street
Raleigh, North Carolina 27602

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. Charles R. Dietz
Plant Manager
Post Office Box 458
Southport, North Carolina 28461

Mr. Franky Thomas, Chairman
Board of Commissioners
Post Office Box 249
Rohivia, North Carolina 28422

Mrs. Chrys Baggett
State Clearinghouse
Budget and Management
116 West Jones Street
Raleigh, North Carolina 27603

Resident Inspector
U. S. Nuclear Regulatory Commission
Star Route 1
Post Office Box 208
Southport, North Carolina 28461

J. Nelson Grace
Regional Administrator
Region II Office
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dayne H. Brown, Chief
Radiation Protection Branch
Division of Facility Services
Department of Human Resources
Post Office Box 12200
Raleigh, North Carolina 27605