

JUN 20 1985

Docket No. 50-388

Pennsylvania Power and Light Company
ATTN: Mr. Bruce D. Kenyon
Vice President Nuclear Operations
2 North Ninth St.
Allentown, Pennsylvania 18101

Gentlemen:

Subject: Inspection Report No. 50-388/84-12

This refers to your letter dated June 7, 1984, in response to our letter dated May 8, 1984.

Our May 8, 1984 letter forwarded a "Notice of Deviation" for surveillance procedures used to test the suppression pool to drywell vacuum breakers which did not provide any quantitative values or instructions to calibrate or verify settings of the vacuum breaker position to those values stated in the FSAR. In your response letter dated June 7, 1984, you disagreed with the "Notice of Deviation" since, in your interpretation, the values provided in the FSAR were for design information and did not constitute calibration criteria. Furthermore, your response provided your reasons for not specifying more precise position indication for the vacuum breakers than is qualitatively established by your plant procedures.

We have reviewed your response considering overall plant safety. Based on our review, we feel that you have established acceptable alternate methods to ensure that vacuum breaker bypass leakage will be maintained below design limits. However, at the time of the inspection, there was no mechanism to verify that the vacuum breakers functioned within the design limits stated in the FSAR.

Based on your response, the NRC evaluation conducted and review of revision 35 to FSAR Section 6.2.1.1.3.2 which deletes the valve position information, we are administratively closing the "Notice of Deviation" issued on May 8, 1984.

We note that exceeding the bypass capability of the plant has a considerable consequence on overall plant safety. Your response states the methods you use to assure that bypass leakage is maintained below the analyzed value. A future inspection will assess the adequacy of your plant procedures and actions taken to assure containment integrity from a bypass leakage standpoint.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By:
Stewart D. Ebnetter

Stewart D. Ebnetter, Director
Division of Reactor Safety

OFFICIAL RECORD COPY

RL SUSQUEHANNA 84-12 - 0001.0.0
04/16/85

8507090507 850620
PDR ADOCK 05000388
Q PDR


11
IE01


cc w/encl:


Norman W. Curtis, Vice President, Engineering and Construction - Nuclear
A. R. Sabol, Manager, Nuclear Quality Assurance
W. E. Barberich, Licensing Engineer
H. W. Keiser, Superintendent of Plant
A. J. Pietrofitta, General Manager, Power Production Engineering and Construction
Atlantic Electric
William Matson
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Commonwealth of Pennsylvania

bcc w/encl:

Region I Docket Room (with concurrences)
DRP Section Chief
J. Grant, DRP


RI:DRS
Piprek/f1
05/7/85


RI:DRS
for Bettenhausen
05/7/85


RI:DRS
Ebnetter
05/23/85

OFFICIAL RECORD COPY

RL SUSQUEHANNA 84-12 - 0002.0.0
05/01/85