



Federal Emergency Management Agency

Washington, D.C. 20472

JUL 5 1985

MEMORANDUM FOR: Edward L. Jordan
Director
Division of Emergency Preparedness and
Engineering Response
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission

FROM: *Richard W. Krimm*
Richard W. Krimm
Assistant Associate Director
Office of Natural and Technological Hazards

SUBJECT: Final Finding on Offsite Radiological Emergency Response
Plans for the River Bend Nuclear Generating Station

Attached is the final finding on the adequacy of the Louisiana Peacetime Radiological Response Plan (Revision V) site-specific to the River Bend Nuclear Generating Station. This finding was prepared by the Region VI Office staff of the Federal Emergency Management Agency.

The remaining NUREG-0654/FEMA REP-1, Rev. 1 evaluative criteria needing correction have been corrected and determined to be adequate. This involved G.3.a., J.10.e., L.3., and P.10 for the State of Louisiana and P.10. for the Parishes.

Consequently, as stated in my memorandum of May 10, 1985, the offsite radiological emergency plans and preparedness are adequate to provide reasonable assurance that appropriate measures can be taken to protect the health and safety of the public in the event of an accident at the River Bend Nuclear Generating Station.

If you have additional questions, please contact Mr. Robert S. Wilkerson, Chief, Technological Hazards Branch, at 646-2861.

Attachment
as stated

8507100007 850705
PDR ADOCK 05000458
F PDR

1E 35 1/1

Listed below are the NUREG-0654 elements which were addressed by the State of Louisiana dated June 11, 1985.

G.3.a. FEMA Evaluation Comment

No physical location was identified for the news media center.

Action taken by State of Louisiana

The Joint Information Center is located in the River Bend Station Training Center. This facility is at the junction of U.S. 61 and the access road to the River Bend site.

The location of the Joint Information Center will be included in the Public Information portion of the next revision to the plan (Chapter 5 of the state plan).

Present Status - Adequate.

J.10.e. FEMA Evaluation Comment

Plan does not contain outline of where KI is to be stored; distribution to be made by LNED.

Action taken by State of Louisiana

A copy of the State's policy regarding KI was submitted to Region VI for review. Two hundred adult doses of KI are available at each of the five local EOC's. Additional doses will be maintained at the EOF for distribution by the State as needed.

Present Status - Adequate.

L.3. FEMA Evaluation Comment

The hospital list does not include the type of facility, capacity, and any special radiological capabilities.

Action taken by the State of Louisiana

Three hospitals have been identified for the handling of off-site contaminated/injured individuals. The following information pertains to these facilities:

<u>Hospital</u>	<u>Capacity</u>	<u>Radiological Capability</u>
Our Lady of the Lake	597	yes
Baton Rouge General	300	yes
West Feliciana	23	yes

This information will be included in the next revision to the plan (Chapter 10 of the State Plan).

Present Status - Adequate.

P.10. FEMA Evaluation Comment

Nothing stated in Implementing Procedures about insuring that telephone numbers are updated at least quarterly.

Action by the State of Louisiana

A statement will be added to the introduction to the implementing procedures as follows: Information on individuals and phone numbers which are included in the implementing procedures will be verified on at least a quarterly basis. Also, this information is already included in State Plan, page 27 Section VIII.D.5.

Present Status - Adequate.