

Docket Nos.: 50-440
and 50-441

MAY 17 1985

Mr. Murray R. Edelman, Vice President
Nuclear Operations Group
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Dear Mr. Edelman:

Subject: Use of ASME Code Case N-413 for the Perry Nuclear
Power Plant (Units 1 and 2)

Your letter dated April 29, 1985 (PY-CEI/NRR-8236L) requested the staff to authorize the use of ASME Code Case N-413 for Perry.

ASME Code Case N-413, "Minimum Size of Fillet Welds for Linear Type Supports Section III, Division 1, Subsection NF" is an acceptable Code Case which is approved as written with no additional requirements other than those specified in the Code Case. The staff expects to have Code Case N-413 endorsed in a future revision of Regulatory Guide 1.84, "Design and Fabrication Code Case Acceptability, ASME Section III, Division 1". Therefore, Code Case N-413 may be used at Perry for linear type supports within the limitation stated in the "Inquiry and Reply" section of Code Case. CEI should document the use of Code Case N-413 in a future FSAR amendment prior to Unit 1 licensing.

Sincerely,

(5)

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

cc: See next page

DISTRIBUTION:

| | | |
|------------------------|-----------|-----------|
| Docket File | JStefano | FCherny |
| NRC PDR | OELD | HBrammer |
| LPDR | ACRS (16) | WJohnston |
| NSIC | EJordan | BDLiaw |
| PRC System | JPartlow | RKirkwood |
| LB#1:DL | BGrimes | |
| MRushbrook | RBosnak | |

LB#1:DL
JStefano:lab
05/17/85

LB#1:DL
BYoungblood
05/17/85

8505300696 850517
PDR ADOCK 05000440
A PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAY 17 1985

Docket Nos.: 50-440
and 50-441

Mr. Murray R. Edelman, Vice President
Nuclear Operations Group
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Dear Mr. Edelman:

Subject: Use of ASME Code Case N-413 for the Perry Nuclear
Power Plant (Units 1 and 2)

Your letter dated April 29, 1985 (PY-CEI/NRR-8236L) requested the staff to authorize the use of ASME Code Case N-413 for Perry.

ASME Code Case N-413, "Minimum Size of Fillet Welds for Linear Type Supports Section III, Division 1, Subsection NF" is an acceptable Code Case which is approved as written with no additional requirements other than those specified in the Code Case. The staff expects to have Code Case N-413 endorsed in a future revision of Regulatory Guide 1.84, "Design and Fabrication Code Case Acceptability, ASME Section III, Division 1". Therefore, Code Case N-413 may be used at Perry for linear type supports within the limitation stated in the "Inquiry and Reply" section of Code Case. CEI should document the use of Code Case N-413 in a future FSAR amendment prior to Unit 1 licensing.

Sincerely,

B. J. Youngblood
For

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

cc: See next page

MAY 17 1985

PERRY

Mr. Murray R. Edelman, Vice President
Nuclear Operations Group
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

cc: Jay Silberg, Esq.
Shaw, Pittman, & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20006

Mr. Larry O. Beck
The Cleveland Electric
Illuminating Company
P. O. Box 97 E-210
Perry, Ohio 44081

Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Parmly at Center Road
Perry, Ohio 44081

Regional Administrator
U. S. NRC, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Donald T. Ezzone, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street
Suite 105
Toledo, Ohio 43624

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047