

## PHILADELPHIA ELECTRIC COMPANY

LIMERICK GENERATING STATION

P. O. BOX 2300

SANATOGA, PA 19464-2300

(215) 327-1200 EXT. 2000

J. DOERING, JR.  
PLANT MANAGER  
LIMERICK GENERATING STATION

February 8, 1993  
Docket Nos. 50-352  
50-353  
License Nos. NPF-39  
NPF-85

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

SUBJECT: Licensee Event Report  
Limerick Generating Station - Units 1 and 2

This LER reports an event which resulted in a condition prohibited by Technical Specifications (TS) where the 'A' Loop of the Emergency Service Water system was inoperable and the required TS actions were not taken in the required time. Additionally, this event resulted in several safety systems being in a condition that alone could have prevented them from performing their safety functions. This event was caused by an equipment failure and personnel errors associated with a Surveillance Test procedure.

Reference: Docket Nos. 50-352  
50-353  
Report Number: 1-91-024  
Revision Number: 01  
Event Date: October 25, 1991  
Discovery Date: October 29, 1991  
Report Date: February 8, 1993  
Facility: Limerick Generating Station  
P.O. Box 2300, Sanatoga, PA 19464-2300

This LER revision is being submitted to revise corrective action commitments. Changes are indicated by revision bar markers in the right hand margin. The original LER was submitted pursuant to the requirements of 10 CFR 50.73(a)(2)(v), 10 CFR 50.73(a)(2)(vii), and 10 CFR 50.73(a)(2)(i)(B).

Very truly yours,

170043

JLP:cah

cc: T. T. Martin, Administrator, Region I, USNRC  
T. J. Kenny, USNRC Senior Resident Inspector, LGS

9302170302 930208  
PDR ADOCK 05000352  
S PDR

JE22