

6.10 RECORD RETENTION

6.10.1 The following records shall be retained for at least five years:

- a. Records of normal station operation including power levels and periods of operation at each power level.
- b. Records of principal maintenance activities, including inspection, repairs, substitution, or replacement of principal items of equipment related to nuclear safety.
- c. ALL REPORTABLE EVENTS.
- d. Records of periodic checks, tests and calibrations.
- e. Records of reactor physics tests and other special tests related to nuclear safety.
- f. Changes to procedures required by Specification 6.8.1.
- g. Records of solid radioactive shipments.
- h. Test results, in units of microcuries, for leak tests performed on licensed sealed sources.
- i. Results of annual physical inventory verifying accountability of licensed sources on record.
- j. Control Room Log Book.
- k. Shift Foreman Log Book.

6.10.2

The following records shall be retained for the duration of Operating License DPR-50 unless otherwise specified in 6.10.1 above.

- a. Records and drawing changes reflecting facility design modifications made to systems and equipment described in the Final Safety Analysis Report.
- b. Records of new and irradiated fuel inventory, fuel transfers and assembly burnup histories.
- c. Routine unit radiation surveys and monitoring records.
- d. Records of radiation exposure history and radiation exposure status of personnel, including all contractors and unit visitors who enter radioactive material areas.
- e. Records of radioactive liquid and gaseous wastes released to the environment, and records of environmental monitoring surveys.
- f. Records of transient or operational cycles for those facility components which affect nuclear safety for a limited number of transients or cycles as defined in the Final Safety Analysis Report.
- g. Records of training and qualification for current members of the unit staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by the Operational Quality Assurance Plan.
- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of reviews by the Independent Onsite Safety Review Group.
- l. Records of analyses required by the radiological environmental monitoring program.
- m. Records of the service lives of all safety related hydraulic snubbers including the date at which the service life commences and associated installation and maintenance records.

6.10.3

The following records shall be retained for the duration of the unit Operating License:

- o. Records of reviews performed for changes made to the OFFSITE DOSE CALCULATION MANUAL and the PROCESS CONTROL PROGRAM.