

JUL 09 1985

In Reply Refer To:
Docket: 50-267

Public Service Company of Colorado
ATTN: O. R. Lee, Vice President
Electric Production
P. O. Box 840
Denver, Colorado 80201

Dear Mr. Lee:

We have reviewed your June 17, 1985 (P-85212), response to our March 11, 1985, request for resolution of our concerns over Beta radiation in liquid effluents. We understand that you are committed to:

1. Perform releases from the Reactor Building sump by a batch method, whereby the sump contents will be sampled and analyzed prior to commencing a release and at 24-hour intervals during the release (we recognized that some addition to the sump may occur during the release period); and
2. Continue the investigation into installing in-line, Beta-sensitive, effluent monitors.

We find these commitments to be an acceptable, interim resolution of our concerns and will include them in the listing of commitments that will be confirmed in connection with our authorization of plant restart.

If you have any questions on this subject, please contact the NRC Project Manager.

Sincerely,

Original Signed
by G.L. Constable

E. H. Johnson, Chief
Reactor Projects Branch 1

cc: (cont. on next page)

RIV:SPES *aw*
PCWagner/lk
7/8/85

SPES *[Signature]*
REIreland
7/8/85

[Signature]
E.H. Johnson
7/8/85

DRSP *R2*
RPDenise
7/8/85

8507240067 850709
PDR ADOCK 05000267
PDR

1/0

Mr. D. W. Warembourg, Manager
Nuclear Engineering Division
Public Service Company of Colorado
P. O. Box 840
Denver, Colorado 80201

Mr. David Alberstein, 14/159A
GA Technologies, Inc.
P. O. Box 85608
San Diego, California 92138

Kelley, Stansfield & O'Donnell
Public Service Company Building
550 15th Street, Room 900
Denver, Colorado 80202

Chairman, Board of County Comm.
of Weld County, Colorado
Greeley, Colorado 80631

Regional Representative
Radiation Programs
Environmental Protection Agency
1860 Lincoln Street
Denver, Colorado 80203

Mr. H. L. Brey, Manager
Nuclear Licensing/Fuels Div.
Public Service Company of Colorado
P. O. Box 840
Denver, Colorado 80201

J. W. Gahm, Manager, Nuclear
Production Division
Fort St. Vrain Nuclear Station
16805 WCR 19½
Platteville, Colorado 80651

L. Singleton, Manager, Quality
Assurance Division
(same address)

Colorado Radiation Control Program Director

bcc distrib. by RIV:

RPB1

EP&RPB

RIV File

K. Heitner, ORB3

K. Heitner, ORB3

W. Gammill, METB/NRR

Resident Inspector
Section Chief (SP&ES)
P. Wagner, RPB1

H. Thompson, D/DL

J. Taylor, IE

F. Congel, RAB/NRR

R. D. Martin, RA

R. Denise, DRS&P

E. Haycraft, DRSP/LA

E. Butcher, ORB3

G. Lainas, DL

E. Jordan, IE