

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the staff on this date.

DMB

Facility: Commonwealth Edison Co.
LaSalle Unit 1
Marseilles, IL 61341
Docket No: 50- 373

Licensee Emergency Classification:
____ Notification of an Unusual Event
____ Alert
____ Site Area Emergency
____ General Emergency
xx Not Applicable

Subject: SHUTDOWN FOR VALVE MAINTENANCE

Unit 1 was shut down on July 12, 1985, for maintenance on two containment valves which had failed local leak rate testing. The two valves are the suppression pool spray valve from the "B" train of the Residual Heat Removal (RHR) system and the shutdown cooling injection valve in the "A" train of the RHR system.

The outage is expected to last until about July 22, 1985. The resident inspectors are monitoring the maintenance activities.

The State of Illinois will be notified.

This information is current as of 11 a.m., July 16, 1985.

CONTACT:

R. Landsman
R. Landsman
FTS 388-5587

N. Chrissotimos
N. Chrissotimos
FTS 388-5716

8507240078 850716
PDR I&E
PNO-III-85-060 PDR

DISTRIBUTION:

H. St. 1:45
Chairman Palladino
Comm. Roberts
Comm. Asselstine
Comm. Bernthal
Comm. Zech
SECY
ACRS
CA
PDR

MNBB 2:10
EDO
PA
MPA
ELD

Phillips 2:25
NRR

Air Rights 2:05
SP

E/W 1:40
IE
OIA
AEOD
INPO 4:08
NSAC 4:00

Willste 2:23
NMSS
RES
MAIL:
ADM:DMB
DOT: Trans Only

LE34

Applicable Resident Site mailed -7-17-85. machine is NOT working
Regions I 3:01, II 3:02, IV 3:48, V 3:57 Licensee (Corporate Office) 3:55