

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Otto L. Maynard
Vice President Plant Operations

February 10, 1993
WO 93-0026


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station Pl-137
Washington, D. C. 20555

Subject: Docket No. 50-482: January, 1993, Monthly
Operating Report

Gentlemen:

Attached is the January, 1993, Monthly Operating Report for Wolf Creek
Generating Station. This submittal is being made in accordance with the
requirements of Technical Specification 6.9.1.8.

Very truly yours,



Otto L. Maynard
Vice President
Plant Operations

OLM/jad

Attachments

cc: J. L. Milhoan (NRC), w/a
G. A. Pick (NRC), w/a
W. D. Reckley (NRC), w/a
T. F. Stetka (NRC), w/a

180055

9302180130 930131
PDR ADOCK 05000482
R PDR

P. Box 411 / Burlington, KS 66839 / Phone: (316) 364-8831
An Equal Opportunity Employer M/F/H/V JET

JE24 11

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

MONTHLY OPERATING REPORT

MONTH: January YEAR: 1993

Docket No.: 50-482

Facility Operating License No.: NPF-42

Report No. 95

Prepared by:

Merlin G. Williams

SUMMARY

The following report highlights the operating experience of Wolf Creek Generating Station for the month of January, 1993. This report is being provided pursuant to Technical Specification 6.9.1.8.

I. SUMMARY OF OPERATING EXPERIENCE

The unit operated at or near 100 percent power through the month of January.

II. MAJOR SAFETY RELATED MAINTENANCE ACTIVITIES

No major safety related maintenance activities were performed during the month of January.

OPERATING DATA REPORT

DOCKE" D. 50-482
 WOLF CREEK GENERATING STATION
 WOLF CREEK NUCLEAR OPERATING CORPORATION
 DATE 02-01-93
 COMPLETED BY M. Williams
 TELEPHONE 316-364-8831

OPERATING STATUS

1. Reporting Period: January, 1993 Gross Hours in Reporting Period: 744
 2. Currently Authorized Power Level(MWt): 3411 Max. Depend. Capacity(MWe-Net): 1131
 Design Electrical Rating (MWe-Net): 1170
 3. Power Level to Which Restricted (If Any)(MWe-Net): N/A
 4. Reasons for restriction (If Any): N/A
- | | This Month | Yr. to Date | Cumulative |
|---|------------------|------------------|--------------------|
| 5. Number of Hours Reactor was Critical | <u>744.0</u> | <u>744.0</u> | <u>52,046.5</u> |
| 6. Reactor Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>339.8</u> |
| 7. Hours Generator on Line | <u>744.0</u> | <u>744.0</u> | <u>51,395.8</u> |
| 8. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>0.0</u> |
| 9. Gross Thermal Energy Generated (MWH) | <u>2,534,643</u> | <u>2,534,643</u> | <u>168,063,778</u> |
| 10. Gross Electrical Energy Generated (MWH) | <u>887,072</u> | <u>887,072</u> | <u>58,479,689</u> |
| 11. Net Electrical Energy Generated (MWH) | <u>853,725</u> | <u>853,725</u> | <u>55,799,854</u> |
| 12. Reactor Service Factor | <u>100.0</u> | <u>100.0</u> | <u>80.1</u> |
| 13. Reactor Availability Factor | <u>100.0</u> | <u>100.0</u> | <u>80.6</u> |
| 14. Unit Service Factor | <u>100.0</u> | <u>100.0</u> | <u>79.1</u> |
| 15. Unit Availability Factor | <u>100.0</u> | <u>100.0</u> | <u>79.1</u> |
| 16. Unit Capacity Factor (Using MDC) | <u>101.5</u> | <u>101.5</u> | <u>75.9</u> |
| 17. Unit Capacity Factor (Using Design MWe) | <u>98.1</u> | <u>98.1</u> | <u>73.4</u> |
| 18. Unit Forced Outage Rate | <u>0.0</u> | <u>0.0</u> | <u>6.3</u> |
19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each): Refueling Outage on March 4, 1993 for 60 days.
 20. If Shut Down at End of Report Period, Estimated Date of Startup: N/A

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-482

WOLF CREEK GENERATING STATION

WOLF CREEK NUCLEAR OPERATING CORPORATION

DATE 02-01-93COMPLETED BY M. WilliamsTELEPHONE 316-364-8831MONTH January, 1993

	DAY AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>1148</u>
2	<u>1148</u>
3	<u>1148</u>
4	<u>1147</u>
5	<u>1148</u>
6	<u>1149</u>
7	<u>1149</u>
8	<u>1148</u>
9	<u>1148</u>
10	<u>1148</u>
11	<u>1148</u>
12	<u>1145</u>
13	<u>1147</u>
14	<u>1146</u>
15	<u>1143</u>
16	<u>1149</u>

	DAY AVERAGE DAILY POWER LEVEL (MWe-Net)
17	<u>1149</u>
18	<u>1148</u>
19	<u>1148</u>
20	<u>1148</u>
21	<u>1149</u>
22	<u>1150</u>
23	<u>1149</u>
24	<u>1146</u>
25	<u>1139</u>
26	<u>1148</u>
27	<u>1143</u>
28	<u>1148</u>
29	<u>1148</u>
30	<u>1146</u>
31	<u>1149</u>

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

UNIT NO. 1

MONTH January, 1993

SUMMARY OF OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reduction or resulted in significant non-load related incidents.

<u>DATE</u>	<u>TIME</u>	<u>EVENT</u>
January 1, 1993	0000 hours	Unit at 100 percent power.
January 31, 1993	2400 hours	Unit at 100 percent power.