

ENCLOSURE 2

NOTICE OF DEVIATION

Florida Power Corporation
Crystal River Unit 3

Docket No. 50-302
License No. DPR-72

The following deviation was identified during an inspection conducted on April 26 - May 24, 1985.

Final Safety Analysis Report (FSAR) section 8.2.3.1 describes the operation of the emergency diesel generator air start system and specifies that the air start system will provide starting air at 225 - 250 psig and that sufficient air is stored in the air reservoirs for six successive start attempts.

Contrary to the above:

- Procedures SP-301 (Shutdown Daily Surveillance Log), SP-300 (Operating Daily Surveillance Log) and SP-354A/B (Emergency Diesel Generator Monthly Test) allow emergency diesel generator air start system pressure to be a minimum of 215 psig;
- On March 29, 1985, the air start system pressure for the "A" Emergency Diesel Generator (EDG-3A) was observed to be at approximately 200 psig; and,
- The licensee is unable to provide justification that six successive start attempts could be accomplished at these reduced air start system pressures.

Please provide, in writing within 30 days of the date of this Notice, a description of corrective actions regarding this deviation, actions taken to avoid further deviations, and the dates when these actions were or will be completed.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: JUN 21 1985

8507100551 850621
PDR ADOCK 05000302
Q PDR

JUN 21 1985

Florida Power Corporation

2

Enclosures:

1. Notice of Violation
2. Notice of Deviation
3. Inspection Report No. 50-302/85-21

cc w/encls:

E. M. Howard, Director
Site Nuclear Operations
P. F. McKee, Nuclear Plant Manager
G. R. Westafer, Manager
Nuclear Operations Licensing
and Fuel Management

bcc w/encls:

NRC Resident Inspector
Document Control Desk
State of Florida

RII

RC
RCarroll:sa
06/14/85

RII

VP
VPanciera
06/14/85

RII

VB
VBrownlee
06/17/85

RII

GJ
GJenkins
06/19/85