

JUL 7 1985

DISTRIBUTION

Docket File  
NRC PDR  
Local PDR  
PRC System  
NSIC  
LB#2 Reading  
EHylton  
DWagner  
Dewey  
ACRS (16)  
JPartlow  
BGrimes  
EJordan  
RKirkwood

Docket No. 50-354

Mr. R. L. Mittl, General Manager  
Nuclear Assurance and Regulation  
Public Service Electric & Gas Company  
P.O. Box 570, T22A  
Newark, New Jersey 07101

Dear Mr. Mittl:

Subject: Use of ASME Code Case N-413 at Hope Creek

The staff has completed its review of your June 7, 1985 request for authorization to use ASME Code Case N-413 for application at Hope Creek.

Code Case N-413, "Minimum Size of Fillet Welds for Linear Type Supports, Section III, Division 1, Subsection NF", is an acceptable Code Case which is approved as written with no additional requirements other than those specified in the Code Case. The Code Case is expected to be endorsed by the NRC in a future revision of Regulatory Guide 1.84, "Design and Fabrication Code Case Acceptability ASME Section III, Division 1".

Code Case N-413 may, therefore, be used at Hope Creek for linear type supports within the limitations stated in the "Inquiry" and "Reply" section of the Code Case. Use of the Code Case should be documented in a future Amendment to the FSAR.

Sincerely,

Walter R. Butler, Chief  
Licensing Branch No. 2  
Division of Licensing

8507100573 850707  
PDR ADOCK 05000354  
A PDR

OFFICE	LB#2/DL/PM	LB#2/DL/BC					
SURNAME	DWagner:mk	WButler					
DATE	7/1/85	7/1/85					



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

JUL 7 1985

Docket No. 50-354

Mr. R. L. Mittl, General Manager  
Nuclear Assurance and Regulation  
Public Service Electric & Gas Company  
P.O. Box 570, T22A  
Newark, New Jersey 07101

Dear Mr. Mittl:

Subject: Use of ASME Code Case N-413 at Hope Creek

The staff has completed its review of your June 7, 1985 request for authorization to use ASME Code Case N-413 for application at Hope Creek.

Code Case N-413, "Minimum Size of Fillet Welds for Linear Type Supports, Section III, Division 1, Subsection NF", is an acceptable Code Case which is approved as written with no additional requirements other than those specified in the Code Case. The Code Case is expected to be endorsed by the NRC in a future revision of Regulatory Guide 1.84, "Design and Fabrication Code Case Acceptability ASME Section III, Division 1".

Code Case N-413 may, therefore, be used at Hope Creek for linear type supports within the limitations stated in the "Inquiry" and "Reply" section of the Code Case. Use of the Code Case should be documented in a future Amendment to the FSAR.

Sincerely,

A handwritten signature in cursive script that reads "Walter R. Butler".

Walter R. Butler, Chief  
Licensing Branch No. 2  
Division of Licensing

Mr. R. L. Mittl  
Public Service Electric & Gas Co.

cc: Gregory Minor  
Richard Hubbard  
Dale Bridenbaugh  
MHB Technical Associates  
1723 Hamilton Avenue, Suite K  
San Jose, California 95125

Troy B. Conner, Jr. Esquire  
Conner & Wetterhahn  
1747 Pennsylvania Avenue N.W.  
Washington, D.C. 20006

Richard Fryling, Jr., Esquire  
Associate General Solicitor  
Public Service Electric & Gas Co.  
P. O. Box 570 T5E  
Newark, New Jersey 07101

Mr. R. Blough  
Resident Inspector  
U.S.N.R.C.  
P. O. Box 241  
Hancocks Bridge, New Jersey 08038

Richard F. Engel  
Deputy Attorney General  
Division of Law  
Environmental Protection Section  
Richard J. Hughes Justice Complex  
CN-112P  
Trenton, New Jersey 08625

Mr. Robert J. Touhey,  
Acting Director  
DNREC - Division of  
Environmental Control  
89 Kings Highway  
P. O. Box 1401  
Dover, Delaware 19903

Mr. R. S. Salvesen  
General Manager-Hope Creek Operation  
Public Service Electric & Gas Co.  
P.O. Box A  
Hancocks Bridge, New Jersey 08038

Mr. B. A. Prestor  
Project Licensing Manager  
Public Service Electric & Gas Co.  
P. O. Box 570 T22A  
Newark, New Jersey 07101

Hope Creek Generating Station

Susan C. Remis  
Division of Public Interest Advocacy  
New Jersey State Department of  
the Public Advocate  
Richard J. Hughes Justice Complex  
CN-850  
Trenton, New Jersey 08625

Office of Legal Counsel  
Department of Natural Resources  
and Environmental Control  
89 Kings Highway  
P.O. Box 1401  
Dover, Delaware 19903

Mr. K. W. Burrowes, Project Engineer  
Bechtel Power Corporation  
50 Beale Street  
P. O. Box 3965  
San Francisco, California 94119

Mr. J. M. Ashley  
Senior Licensing Engineer  
c/o Public Service Electric & Gas Co.  
Bethesda Office Center, Suite 550  
4520 East-West Highway  
Bethesda, Maryland 20814

Mr. A. E. Giardino  
Manager - Quality Assurance E&C  
Public Service Electric & Gas Co.  
P. O. Box A  
Hancocks Bridge, New Jersey 08038

Mr. Anthony J. Pietrofitta  
General Manager  
Power Production Engineering  
Atlantic Electric  
1199 Black Horse Pike  
Pleasantville, NJ 08232

Mr. Thomas E. Murley  
U. S. NRC, Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406