


VERMONT YANKEE
NUCLEAR POWER CORPORATION



P.O. Box 157, Governor Hunt Road
Vernon, Vermont 05354-0157
(802) 257-7711

February 10, 1993
VY-RCE-93-006
BVY 93-013

U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attn: Document Control Desk

Reference: a) License No. DPR-28 (Docket No. 50-271)

Dear Sir:

Submitted herewith is the Monthly Statistical Report for the Vermont
Yankee Nuclear Power Station for the month of January 1993.

Very truly yours,

Vermont Yankee Nuclear Power Corporation

James P. Pelletier
Vice President, Engineering

cc: USNRC, Region I
USNRC Resident Inspector, VYNPS

DP 0411 Rev. 4
Page 1 of 1

18-124

9302180131 930131
PDR ADOCK 05000271
R PDR

JE24 1/1

VERMONT YANKEE NUCLEAR POWER STATION

MONTHLY STATISTICAL REPORT 93-01

FOR THE MONTH OF JANUARY 1993

OPERATING DATA REPORT

DOCKET NO. 50-271
DATE 930210
COMPLETED BY G.A. WALLIN
TELEPHONE (802)257-7711

OPERATING STATUS

1. Unit Name: Vermont Yankee

2. Reporting Period: January

3. Licensed Thermal Power (MWT): 1593

4. Nameplate Rating (Gross MWe): 540

5. Design Electrical Rating (Net MWe): 514 (oc) 504 (cc)

6. Maximum Dependable Capacity (Gross MWe): 535

7. Maximum Dependable Capacity (Net MWe): 504

8. If changes, occur in capacity ratings (Items Number 3 through 7) since last report, give reasons:

N/A

9. Power level to which restricted, if any (Net MWe): N/A

10. Reasons for restrictions, if any: N/A

	This Month	Yr-to-Date	Cumulative
11. Hours in Reporting Period	744.00	744.00	176808.00
12. Number Of Hours Reactor was Critical	744.00	744.00	144940.35
13. Reactor Reserve Shutdown Hours	0.00	0.00	0.00
14. Hours Generator On-Line	744.00	744.00	141998.64
15. Unit Reserve Shutdown Hours	0.00	0.00	0.00
16. Gross Thermal Energy Generated (MWH)	1184133.50	1184133.50	211255199.50
17. Gross Electrical Energy Generated	399919.00	399919.00	70385077.00
18. Net Electrical Energy Generated (MWH)	384517.00	384517.00	66859392.00
19. Unit Service Factor	100.00	100.00	79.55
20. Unit Availability Factor	100.00	100.00	79.55
21. Unit Capacity Factor (Using MDC Net)	102.54	102.54	74.31
22. Unit Capacity Factor (Using DER Net)	100.55	100.55	72.87
23. Unit Forced Outage Rate	0.00	0.00	5.17
24. Shutdowns scheduled over next 6 months (Type, Date, and Duration of Each):	<u>N/A</u>		

25. If shut down at end of report period, estimated date of startup: N/A

26. Units In Test Status (prior to commercial operation): N/A

Forecast Achieved

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-271
 UNIT Vermont Yankee
 DATE 930210
 COMPLETED BY G.A. WALLIN
 TELEPHONE (802)257-7711

MONTH January

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>517</u>
2.	<u>517</u>
3.	<u>516</u>
4.	<u>517</u>
5.	<u>517</u>
6.	<u>517</u>
7.	<u>517</u>
8.	<u>517</u>
9.	<u>517</u>
10.	<u>516</u>
11.	<u>516</u>
12.	<u>516</u>
13.	<u>516</u>
14.	<u>516</u>
15.	<u>516</u>
16.	<u>517</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>517</u>
18.	<u>517</u>
19.	<u>519</u>
20.	<u>517</u>
21.	<u>517</u>
22.	<u>517</u>
23.	<u>517</u>
24.	<u>517</u>
25.	<u>517</u>
26.	<u>517</u>
27.	<u>517</u>
28.	<u>517</u>
29.	<u>517</u>
30.	<u>517</u>
31.	<u>516</u>

INSTRUCTIONS:

On this format, list the average daily unit power level in MWF-Net for each day in the reporting month. Compute to the nearest whole megawatt.

VYDPF 0411.02
 DP 0411 Rev. 4
 Page 1 of 1
 RT No. 13.F01.18V

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH JANUARYDOCKET NO 50-271UNIT NAME Vermont YankeeDATE 930210COMPLETED BY G.A. WallinTELEPHONE (802)257-7711

No.	Date	1 Type	Duration (hours)	2 Reason	3 Method of Shutting Down Reactor	License Event Report #	4 System Code	5 Component Code	Cause and Corrective Action to Prevent Recurrence
(None)									

1 F: Forced
S: Scheduled

2 Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training and
License Examination
F-Administrative
G-Operational Error (Explain)
H-(Explain) -

3 Method:
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Other (Explain)

4 Exhibit G- Instructions
for Preparation of Data
Entry Sheets for License
Event Report (LER) File
(NUREG 0161)

5 Exhibit I - Same Source

DOCKET NO. 50-271
DATE 930210
COMPLETED BY G.A. WALLIN
TELEPHONE (802)257-7711

REPORT MONTH January

SUMMARY OF OPERATING EXPERIENCES

Highlights

Vermont Yankee operated at 99.9% of rated thermal power for the month. Gross electrical generation was 399,919 MWh or 99.5% design electrical capacity.

Operating Summary

The following is a chronological description of plant operations including other pertinent items of interest for the month:

At the beginning of the reporting period the plant was operating at 99.9% of rated thermal power.

There were no items of interest to report for this month.

At the end of the reporting period the plant was operating at 99.9% of rated thermal power.