

ENCLOSURE 1

NOTICE OF VIOLATION

Georgia Power Company
Hatch

Docket No. 50-366
License No. NPF-5

The following violation was identified during an inspection conducted on April 28 - May 24, 1985. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

Technical Specification 4.8.2.6.1.a.2 requires that the functional test for molded case circuit breakers (MCBs) shall consist of injecting a current input at the specified setpoint to the circuit breaker and verifying that the circuit breaker functions as designed.

Contrary to the above, MCBs were being tested per Hatch procedure HNP-2-3850 which requires the injection of current at a magnitude greater than that specified as the trip set point in the Technical Specifications. This testing method is in accordance with National Electrical Manufacturers Association Standards and is technically sound, but is not in compliance with Technical Specifications.

This is a Severity Level IV violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

JUN 21 1985

Date: _____

8507110113 850621
PDR ADOCK 05000321
g PDR