

ENCLOSURE 1

NOTICE OF VIOLATION

Georgia Power Company  
Vogtle 1 and 2

Docket Nos. 50-424 and 50-425  
License Nos. CPPR-108 and CPPR-109

The following violation was identified during an inspection conducted on April 29 - May 3, 1985. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 50, Appendix B, Criterion VII, Control of Purchased Material, Equipment, and Services, states that documentary evidence that material conforms to the procurement requirements shall be available at the nuclear power plant. Chapter 3.1.4 of Vogtle Final Safety Analysis Report endorses the ASME Boiler and Pressure Vessel Code, Section III. The ASME Code Article NB2540 requires examination of bars by ultrasonic methods.

Contrary to the above, the certified material test report for the 1½-inch x ¾-inch flow restrictor on Purchase Order PAV-5721, Change Notice 90, purchased from Consolidated Pipe and Supply and manufactured by Stainless Products does not contain evidence of ultrasonic inspection.

This is a Severity Level IV violation (Supplement II).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: June 10, 1985

8507110243 850610  
PDR ADOCK 05000424  
Q PDR