

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) R.E. Ginna Nuclear Power Plant										DOCKET NUMBER (2) 0 5 0 0 0 2 4 4										PAGE 13 1 OF 0 2																			
TITLE (4) Manual Actuation of Engineered Safety Feature																																							
EVENT DATE (6) 0 5 3 1 8 5 8 5										LER NUMBER (8) 0 1 3 0 0										REPORT DATE (7) 0 6 2 8 8 5										OTHER FACILITIES INVOLVED (9) FACILITY NAME: DOCKET NUMBER(S): 0 5 0 0 0									
OPERATING MODE (5) N										THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)										73.71(b) 73.71(c) OTHER (Specify in Abstract below and in Text, NRC Form 305A)																			
POWER LEVEL (10) 1 1 0 1 0										20.402(b) 20.402(a)(1)(i) 20.402(a)(1)(ii) 20.402(a)(1)(iii) 20.402(a)(1)(iv) 20.402(a)(1)(v)										20.408(a) 20.36(a)(1) 20.36(a)(2) 20.73(a)(2)(i) 20.73(a)(2)(ii) 20.73(a)(2)(iii) 20.73(a)(2)(iv)										20.73(a)(2)(iv) 20.73(a)(2)(v) 20.73(a)(2)(vi) 20.73(a)(2)(vii)(A) 20.73(a)(2)(vii)(B) 20.73(a)(2)(viii)									
LICENSEE CONTACT FOR THIS LER (12) NAME: G.F. Larizza, Operations Manager																														TELEPHONE NUMBER AREA CODE: 3 1 5 5 2 4 - 4 4 4 6									
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																																							
CAUSE SYSTEM COMPONENT MANUFACTURER REPORTABLE TO NRC										CAUSE SYSTEM COMPONENT MANUFACTURER REPORTABLE TO NRC																													
C E K - - D G A 1 5 2 N																																							
SUPPLEMENTAL REPORT EXPECTED (14) YES (If yes, complete EXPECTED SUBMISSION DATE) X NO																														EXPECTED SUBMISSION DATE (15) MONTH DAY YEAR									

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

At 2030 hours on May 31, 1985, Power Control personnel of Rochester Gas & Electric notified the Ginna Station Control Room personnel that a Tornado Warning had been declared by the U.S. Weather Bureau for the general area of Wayne County. Ginna Station Site Contingency Procedure SC-2 "Adverse Weather Emergency Plan" states that one emergency diesel generator (D/G) is to be started and tied to a safeguard bus whenever tornados are known to be in the vicinity of the plant area.

In accordance with the above requirement at 2039 hours the "A" D/G was started and tied to safeguard Bus 18.

8507110277 850628
PDR ADOCK 05000244
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104

EXPIRES 9/31/85

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (8)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
R.E. Ginna Nuclear Power Plant	0 5 0 0 0 2 4 4 8 5	-	0 1 3	-	0 0 0	2	OF 0 2

TEXT (If more space is required, use additional NRC Form 368A's) (17)

On May 31, 1985, while Ginna Station was operating at 100% power, the area around Ginna Station was being effected by adverse weather conditions. As a result of this adverse weather condition, Rochester Gas & Electric Power control personnel notified the Ginna Station Control Room personnel that a tornado warning had been declared by the U.S. Weather Bureau for the general area of Wayne County.

In accordance with the requirements of Ginna Station Site Contingency Procedure SC-2 "Adverse Weather Emergency Plan," the Control Room personnel at 2039 hours started the "A" Diesel Generator as per procedure T-27.4 "Diesel Generator Operation" which required the D/G to be run tied to a safeguard bus (Bus 18 in this case) which in turn has been separated from its normal power supply.

At approximately 2124 hours the tornado warning had been rescinded and the "A" D/G was removed from service at 2132 hours. Thus at no time during this event was the station operated in a degraded mode or in a unanalyzed condition.



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

ROGER W. KOBER
VICE PRESIDENT
ELECTRIC & STEAM PRODUCTION

TELEPHONE
AREA CODE 716 546-2700


June 28, 1985

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: LER 85-013, Manual Actuation of Engineered Safety
Feature
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

In accordance with 10 CFR 50.73, Licensee Event Report System, item (a)(2)(iv) which requests a report of, "any event or conditions that resulted in a manual or automatic actuation of any Engineered Safety Feature (ESF)", the attached Licensee Event Report LER 85-013 is hereby submitted.

Very truly yours,


Roger W. Kober

RWK/eeg

xc: U.S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

IE22
1/1