

Yellow

June 13, 1985

Georgia Power Company
ATTN: Mr. R. J. Kelly
Executive Vice President
P. O. Box 4545
Atlanta, GA 30302

Gentlemen:

SUBJECT: MEETING SUMMARY

This letter transmits the Meeting Summary for the meeting held between Mr. H. E. Nix, General Manager, Plant Hatch, of Georgia Power Company, and Dr. J. Nelson Grace, Regional Administrator, NRC, Region II, and staff members of each organization on May 24, 1985. The meeting was held in the Region II offices, Atlanta, Georgia, and concerned Plant Hatch requalification examinations.

Region II believes that previous resolution of your concerns was accurate and proper. However, the examination answer key for Question 8.04 has been revised to allow for a more equitable evaluation of the candidate's knowledge. Details of the subjects discussed are enclosed in the Meeting Summary.

In accordance with Section 2.790 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosure will be placed in the NRC's Public Document Room.

Should you have any questions concerning this matter, we will be pleased to discuss them.

Sincerely,

(Original signed by JNGrace)

J. Nelson Grace
Regional Administrator

Enclosure:
Meeting Summary

cc w/encl: (See page 2)

8507110322 850613
PDR ADOCK 05000321
PDR

11
IE 45

June 13, 1985

cc w/encl:

J. T. Beckham, Vice President and
General Manager - Nuclear Operations
H. C. Nix, Site General Manager
P. E. Fornel, Site QA Supervisor
L. Gucwa, Chief, Nuclear Engineer
J. Badgett, Manager, Nuclear Training
Corporate
C. T. Moore, Manager, Nuclear Training
Plant Hatch

bcc w/encl:

NRC Resident Inspector
Hugh S. Jordan, Executive Secretary
Document Control Desk
State of Georgia

RII
BAW
BAWilson:11
06/5/85

RII
AFG
AFGibson
06/5/85

~~RII~~
~~PRBemis~~
~~06/ /85~~

RII
VPanciera
06/10/85

RII
RDW
RDWalker
06/10/85

RII
JA
JAOlshinski
06/11/85

ENCLOSURE

MEETING SUMMARY

Licensee: Georgia Power Company

Facility: Hatch Nuclear Plant, Units 1 and 2

Docket Nos: 50-321 and 50-366

SUBJECT: HATCH REQUALIFICATION EXAMINATIONS

On May 24, 1985, representatives of Georgia Power Company (GPC) met with NRC Region II personnel in Atlanta, Georgia, to discuss the requalification examination conducted at Plant Hatch during the week of March 11, 1985, (OL-50-321/85-01). The meeting was held at the request of Georgia Power Company. The purpose was to appeal the resolutions from the April 23, 1985 meeting between the Region II staff and GPC. Agenda items were unchanged from the April 23 meeting. An attendance list is attached as Attachment A to this summary.

After opening remarks by Mr. J. Badgett, Mr. C. T. Moore presented Georgia Power's analysis of selected examination items. This analysis was limited to Section 8 of the Senior Operator written examination (Administrative Procedures, Conditions, and Limitations). It was the opinion of GPC that this section was the most substantive for displaying items whose impact was significant. The specific methodology by which the evaluation was made, the deduced implications on the accelerated requalification training program, and the resultant concerns with specific questions (to include corrective recommendations) constituted the background information provided by the briefing. The Region's response (letter of May 3, 1985) was then summarized and rebutted.

Attachment B is the revised answer key with justification, for Question 8.04. For all other questions, the examination and answer key will remain unchanged. All questions are considered to be both relevant and definitive. The specific comments presented previously by the staff are still considered to be valid and appropriate. As a generic statement, aids and support devices do not remove the onus of responsibility from the licensed operator. The requirements for familiarity with, and understanding of, the basis and application of operating procedures remain unchanged. Similarly, candidates are expected to have a thorough knowledge of Technical Specifications, the bases for the requirements and means to comply with the requirements.


Review of individual performance on the written exam shows that no final statuses will be changed based upon the answer key modifications made. Individuals will, however, be contacted concerning their revised scores.

Enclosure

2

June 13, 1985

With respect to the request for waiver made by Georgia Power concerning the July exams, a response will be made by June 15, 1985.


Ken E. Brockman, Reactor Engineer

Attachments:

- A. Attendance List
- B. Revised Answer Key

ATTACHMENT A

ATTENDANCE LIST

Georgia Power Company

J. J. Badgett, Corporate Nuclear Training Manager
W. E. Burns, Nuclear Engineering & Evaluation Manager
C. T. Moore, Training Manager, Plant Hatch
H. E. Nix, General Manager, Plant Hatch

Nuclear Regulatory Commission, Region II

J. N. Grace, Regional Administrator
J. A. Olshinski, Deputy Regional Administrator
A. F. Gibson, Chief, Operations Branch
V. L. Brownlee, Chief, Projects Branch #2
B. A. Wilson, Chief, Operator Licensing Section
K. E. Brockman, Reactor Engineer
R. Carroll, Project Engineer
R. Butcher, Senior Resident Inspector

ATTACHMENT B

ANSWER KEY (REVISED)

8.04 Unit 2 Technical Specifications specify the frequency intervals for the performance of Surveillance requirements. This is accomplished by use of FREQUENCY NOTATION.

COMPLETE the following table. (DO NOT INCLUDE GRACE PERIODS)

| | <u>NOTATION</u> | <u>FREQUENCY</u> |
|----|-----------------|--------------------------------|
| a. | S | At least once per _____ hours. |
| b. | Q | At least once per _____ days. |
| c. | M | At least once per _____ days. |
| d. | _____ | At least once per 18 months. |

ANSWER:

| | | |
|----|----------------------------|--------|
| a. | 12 hours (+0, -25% @ 0.20) | (0.25) |
| b. | 92 days (+0, -25% @ 0.20) | (0.25) |
| c. | 31 days (+0, -25% @ 0.20) | (0.25) |
| d. | R | (0.25) |

Justification: Acceptability of conservative response in accordance with the allowable "grace period," as defined within the surveillance program.