

official

JUN 07 1985

Carolina Power and Light Company
ATTN: Mr. E. E. Utley
Executive Vice President
Power Supply and Engineering
and Construction
411 Fayetteville Street
Raleigh, NC 27602

Gentlemen:

SUBJECT: DOCKET NO. 50-261 - H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
RADIOLOGICAL PLAN REVIEW

We have completed our review of Revisions 4, 5, 7, and 8 to the H. B. Robinson Radiological Emergency Plan.

Our review indicates that your H. B. Robinson Radiological Emergency Plan continues to meet the planning standards of 10 CFR 50.54(q) and the requirements of Appendix E to 10 CFR Part 50. However, during the review it was noted that two changes appeared to be inconsistent with the evaluation criteria in NUREG-0654, Revision 1. The specific changes were (1) the calibration frequency for the meteorological instrumentation, and (2) the partial redesignation of the backup hospital and the Lee County warning point (Section 3 not in agreement with the changes to Appendix B). It is our understanding, based on discussions with members of your staff, that during your next revision of the plan these matters will be handled, respectively, by (1) referencing the appropriate implementing procedures and (2) updating Section 3 to reflect changes in designated offsite support organizations. If your understanding of the disposition of these matters is different from the above, please advise.

Please be reminded that 10 CFR 50.54(q) requires NRC approval of any changes to your plan that may decrease the effectiveness of the plan. However, if your safety review indicates no decrease in the level of emergency preparedness, then changes can be made without NRC approval. In all cases, you should furnish copies of each change to the NRC in accordance with 10 CFR 50.54(q). Also, any changes to the Emergency Plan Implementing Procedures should be made in accordance with the requirements of 10 CFR Part 50, Appendix E, Section V.

Should you have any questions regarding this letter, please contact Mr. W. E. Cline of our staff at 404/221-2665.

Sincerely,

David M. Verrelli, Chief
Reactor Projects Branch 1
Division of Reactor Projects

cc: (See page 2)

8507110458 850607
PDR ADOCK 05000261
F PDR

110

IE35

cc: G. P. Beatty, Jr., Manager
Robinson Nuclear Project
Department
R. E. Morgan, Plant
General Manager

bcc: NRC Resident Inspector
Document Control Desk
EP Section Chief
EPRP Branch File
State of North Carolina

RII

JKreh

6/4/85

RII

WCline

6/4/85

RII

DCollins

6/6/85

RII

APardin

6/6/85

RII

~~PFredrickson~~

~~6/7/85~~