

official

JUN 06 1985

Georgia Power Company  
ATTN: Mr. R. J. Kelly  
Executive Vice President  
P. O. Box 4545  
Atlanta, GA 30302

Gentlemen:

SUBJECT: EMERGENCY NOTIFICATION SYSTEM (ENS) - HATCH NUCLEAR POWER PLANT

This letter responds to your letter of April 13, 1984, regarding the establishment of ENS extension from the control room simulator to the Emergency Operations Facility.

This issue has been discussed with the NRC Telecommunications Branch, Division of Facilities and Operations Support/ADM. The Telecommunications Branch has advised us that the addition of this line could result in degradation of the quality of the emergency notification system; therefore, this request is disapproved. Further discussion on this subject should be directed to the NRC Telecommunications Branch in Washington, DC. Questions regarding this matter should be referred to the Telecommunications Branch Chief, Mr. Thomas Kellam at (202) 492-8070.

Sincerely,

Virgil L. Brownlee, Chief  
Reactor Project Branch 2  
Division of Reactor Projects

cc: J. T. Beckham, Vice President  
and General Manager  
H. C. Nix, Site General Manager  
P. E. Fornel, Site QA Supervisor  
L. Gucwa, Chief Nuclear Engineer

bcc: E. Reise, ELD  
~~M. Sinkule, RII~~  
NRC Resident Inspector  
Document Control Desk  
State of Georgia  
Hugh S. Jordan, Executive Secretary  
Georgia Public Service Commission

RII

MP Brown  
6/3/85

RII

WCline  
6/3/85

RII

DCollins  
6/3/85

RII

VPanciera  
6/4/85

8507110596 850606  
PDR ADOCK 05000321  
F PDR

110  
IE35