

Commonwealth Edison Company  
Quad Cities Generating Station  
22710 206th Avenue North  
Cordova, IL 61242-9740  
Tel 309-654-2241

LWP-96-071



October 7, 1996

U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station  
Docket Number 50-254, DPR-29, Unit One  
Docket Number 50-265, DPR-30, Unit Two

Enclosed is Licensee Event Report (LER) 96-020, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(v)(D). The licensee shall report any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems that are needed to mitigate the consequences of an accident.

The following commitments are being made by this letter:

1. A description of this event will be presented to Licensed Operations personnel in retraining by 01/31/97.
2. QCOS 5750-02, "Control Room Emergency Filtration System Monthly Test," will be revised by 10/27/96.

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3602.

Respectfully,

COMMONWEALTH EDISON COMPANY  
QUAD CITIES NUCLEAR POWER STATION

*L. W. Pearce for*

L. W. Pearce  
Station Manager

LWP/CP/plm  
Enclosure

cc: A. B. Beach, Regional Administrator, Region III  
R. M. Pulsifer, Project Manager, NRR  
C. Miller, Senior Resident Inspector, Quad Cities  
R. J. Singer, Mid American Energy Company  
D. C. Tubbs, Mid American Energy Company  
P. Piet, Licensing, ComEd  
F. Spangenberg, Regulatory Affairs Manager, Dresden  
INPO Records Center

150070

9610160175 961007  
PDR ADOCK 05000254  
S PDR

*IER 22*  
*11/1*