



GPU Nuclear Corporation  
Post Office Box 480  
Route 441 South  
Hiddletown, Pennsylvania 17057-0191  
717 944-7621  
TELEX 84-2386  
Writer's Direct Dial Number:  
(717) 948-8400

February 11, 1993  
C312-93-2008  
C000-93-2009

US Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Three Mile Island Nuclear Station Unit 2 (TMI-2)  
Operating License No. DPR-73  
Docket No. 50-320  
Response to NRC Bulletin 90-01, Supp. 1

Dear Sir:

NRC Bulletin 90-01, Supplement 1, addresses potential failure mechanisms for Rosemount transmitters, Models 1153 and 1154. GPU Nuclear has verified that no Model 1153 or Model 1154 transmitters manufactured by Rosemount are utilized at TMI-2 on any important-to-safety system or system installed in accordance with 10 CFR 50.62. Thus, the Requested Actions for Operating Reactors have been satisfied, even though TMI-2 is no longer an operating reactor.

Sincerely Yours,

R. L. Long  
Director, Corporate Services/TMI-2

EDS/dlb

cc: T. T. Martin - Regional Administrator, Region I  
M. T. Masnik - Project Manager, PDNP Directorate  
L. H. Thonus - Project Manager, TMI  
F. I. Young - Senior Resident Inspector, TMI

7302220319 930211  
PDR ADOCK 05000320  
PDR

GPU Nuclear Corporation is a subsidiary of the General Public Utilities Corporation

JE39 1/0