



SCIENTIFIC SERVICES & SYSTEMS GROUP

February 12, 1993

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

Subject: Update on Notification of Potential Part 21

Gentlemen:

This letter is a notice of closure on Wyle's letter of September 29, 1992 "Notification by Wyle Laboratories of a potential defect of a basic component."

As previously noted, of January 11, 1991, Wyle Laboratories delivered Eight (8) Solenoid Manifold Assemblies, P/N C6930-060, Wyle Codes GRE-001 through GRE-008, manufactured by Automatic Valve (AVC) of Novi, Michigan to the Tennessee Valley Authority's Browns Ferry Nuclear Plant.

These Solenoid Manifold Assemblies were certified by Wyle Report Number 30081-99 (Job Number 41430) through a Commercial Grade dedication program to be qualified to the requirements of Wyle Report 17514-1, Revision A, which included NURED -0588, Category I.

The defect was that Wyle Report 30081-99 does not provide sufficient evidence that the above noted serial numbers are qualified by similarity to Wyle Report 17514-1, Revision A.

Wyle had supplied these Solenoid Manifold Assemblies only to Browns Ferry as noted above.

TVA returned to Wyle all eight of the Solenoid Manifold Assemblies on October 5, 1992.

Wyle has now completed the similarity analysis, documented the analysis in Wyle Report 30081-99, Revision A (see enclosed copy) and has demonstrated that the AVC Manifolds, P/N C6930-060, Wyle S.Ns GRE001 through GRE-011 are similar to the original test specimen and are qualified to the conditions of Wyle Report 17514-1, Revision A.

220112

9302230323 930212  
PDR ADDCK 05000259  
S PDR

*change: INFO record Ctr.  
NRC PDR  
NSIC Silver, E*

*Ltr. Encl.*

*1 0  
1 0  
1 0*


*JE19*

U.S. Nuclear Regulatory Commission  
February 12, 1993  
Page 2

Wyle has returned the eight Solenoid Manifold Assemblies to TVA on February 11, 1993.

Sincerely,

**WYLE LABORATORIES**  
**Eastern Operations**

  
Edward W. Smith  
Director, Contracts and Purchasing

EWS/jrd

cc: Mr. Lief Norrholm  
Chief, Vendor Inspection Branch  
Division of Reactor Inspection and Safeguards  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission, Mail Stop 9D4  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852

TVA, Nuclear Power  
Nuclear Licensing and Regulatory Affairs  
Attention: Manager, Technical Licensing Services  
LP 5N 156B  
1101 Market Street  
Chattanooga, TN 37402-2801

TVA  
Contracting Officer  
Janet E. Keith  
1101 Market Street  
Chattanooga, TN 37402-2801

Automatic Valve Corporation  
Mr. Todd Hutchins  
P.O. Box 435  
41144 Vincenti Court  
Novi, MI 48050-0435