

Docket No. 50-440

February 18, 1993

Mr. Robert A. Stratman, Vice President  
Nuclear - Perry  
The Cleveland Electric Illuminating  
Company  
10 Center Road  
Perry, Ohio 44081

Dear Mr. Stratman:

SUBJECT: ANNUAL ECCS OUTAGE REPORT (TAC NO. M76180)

By letter dated February 28, 1990, you informed the NRC staff that you would no longer submit an annual Emergency Core Cooling System (ECCS) outage report to the NRC. Instead, you will utilize your ongoing involvement with the Institute of Nuclear Power Operations Nuclear Plant Reliability Data System and the 10 CFR 50.73 reporting requirements in order to identify significant ECCS component failures and reliability data for the ECCS systems.

The NRC staff has reviewed the change to your ECCS outage reporting commitment and finds that it is acceptable. Contact me if you have any questions.

Sincerely,

original signed by

Jon B. Hopkins, Sr. Project Manager  
Project Directorate III-3  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

cc:  
See next page

DISTRIBUTION

~~Bucket File~~

PDIII-3 r/f  
JRoe  
JHannon  
JHopkins  
ARCS(10)  
PKreutzer

NRC & Local PDRs  
PDIII-Plant File  
JZwolinski  
RJones  
OGC  
EGreenman, RIII

LA:PDIII-3  
PKreutzer  
2/17/93

JBH  
PM:PDIII-3  
JHopkins:sw  
2/17/93

SRXB:NRR  
RJones  
2/17/93

H  
D:PDIII-3  
JHannon  
2/18/93

9302250092 930218  
PDR ADOCK 05000440  
PDR

DO NOT WRITE IN THESE SPACES  
DO NOT WRITE IN THESE SPACES

February 18, 1993

Mr. Robert A. Stratman, Vice President  
Nuclear - Perry  
The Cleveland Electric Illuminating  
Company  
10 Center Road  
Perry, Ohio 44081

Dear Mr. Stratman:

SUBJECT: ANNUAL ECCS OUTAGE REPORT (TAC NO. M76180)

By letter dated February 28, 1990, you informed the NRC staff that you would no longer submit an annual Emergency Core Cooling System (ECCS) outage report to the NRC. Instead, you will utilize your ongoing involvement with the Institute of Nuclear Power Operations Nuclear Plant Reliability Data System and the 10 CFR 50.73 reporting requirements in order to identify significant ECCS component failures and reliability data for the ECCS systems.

The NRC staff has reviewed the change to your ECCS outage reporting commitment and finds that it is acceptable. Contact me if you have any questions.

Sincerely,

original signed by

Jon B. Hopkins, Sr. Project Manager  
Project Directorate III-3  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

cc:  
See next page

DISTRIBUTION

Docket File	NRC & Local PDRs
PDIII-3 r/f	PDIII-Plant File
JRoe	JZwolinski
JHannon	RJones
JHopkins	OGC
ARCS(10)	EGreenman, RIII
PKreutzer	

LA:PDIII-3  
PKreutzer  
2/17/93

JBH  
PM:PDIII-3  
JHopkins:sw  
2/17/93

SRXB:NRR  
RJones  
2/17/93

D:PDIII-3  
JHannon  
2/18/93



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

February 18, 1993

Docket No. 50-440

Mr. Robert A. Stratman, Vice President  
Nuclear - Perry  
The Cleveland Electric Illuminating  
Company  
10 Center Road  
Perry, Ohio 44081

Dear Mr. Stratman:

SUBJECT: ANNUAL ECCS OUTAGE REPORT (TAC NO. M76180)

By letter dated February 28, 1990, you informed the NRC staff that you would no longer submit an annual Emergency Core Cooling System (ECCS) outage report to the NRC. Instead, you will utilize your ongoing involvement with the Institute of Nuclear Power Operations Nuclear Plant Reliability Data System and the 10 CFR 50.73 reporting requirements in order to identify significant ECCS component failures and reliability data for the ECCS systems.

The NRC staff has reviewed the change to your ECCS outage reporting commitment and finds that it is acceptable. Contact me if you have any questions.

Sincerely,

A handwritten signature in cursive script, reading "Jon B. Hopkins", is written over the typed name.

Jon B. Hopkins, Sr. Project Manager  
Project Directorate III-3  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

cc:  
See next page

Mr. Robedrt A. Stratman  
Cleveland Electric Illuminating Company

Perry Nuclear Power Plant  
Unit Nos. 1 and 2

cc:

Jay E. Silberg, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N Street, N.W.  
Washington, D.C. 20037

Mr. James W. Harris, Director  
Division of Power Generation  
Ohio Department of Industrial Relations  
P. O. Box 825  
Columbus, Ohio 43216

Mary E. O'Reilly  
Centerior Energy Corporation  
300 Madison Avenue  
Toledo, Ohio 43652

The Honorable Lawrence Logan  
Mayor, Village of Perry  
4203 Harper Street  
Perry, Ohio 44081

Resident Inspector's Office  
U.S. Nuclear Regulatory Commission  
Parmly at Center Road  
Perry, Ohio 44081

The Honorable Robert V. Orosz  
Mayor, Village of North Perry  
North Perry Village Hall  
4778 Lockwood Road  
North Perry Village, Ohio 44081

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Attorney General  
Department of Attorney General  
30 East Broad Street  
Columbus, Ohio 43216

Frank P. Weiss, Esq.  
Assistant Prosecuting Attorney  
105 Main Street  
Lake County Administration Center  
Painesville, Ohio 44077

Radiological Health Program  
Ohio Department of Health  
Post Office Box 118  
Columbus, Ohio 43266-0118

Ms. Sue Hiatt  
OCRE Interim Representative  
8275 Munson  
Mentor, Ohio 44060

Ohio Environmental Protection Agency  
DERR--Compliance Unit  
ATTN: Zack A. Clayton  
P. O. Box 1049  
Columbus, Ohio 43266-0149

Terry J. Lodge, Esq.  
618 N. Michigan Street, Suite 105  
Toledo, Ohio 43624

Mr. Phillip S. Haskell, Chairman  
Perry Township Board of Trustees  
4171 Main Street, Box 65  
Perry, Ohio 44081

John G. Cardinal, Esq.  
Prosecuting Attorney  
Ashtabula County Courthouse  
Jefferson, Ohio 44047

State of Ohio  
Public Utilities Commission  
East Broad Street  
Columbus, Ohio 43266-0573

Mr. Kevin P. Donovan  
Cleveland Electric  
Illuminating Company  
Perry Nuclear Power Plant  
P. O. Box 97, E-210  
Perry, Ohio 44081

David P. Igyarto, General Manager  
Cleveland Electric Illuminating Company  
Perry Nuclear Power Plant  
Post Office Box 97, SB306  
Perry, Ohio 44081