

Appendix

NOTICE OF VIOLATION

Union Electric Company

Docket No. 50-483

As a result of the inspection conducted on March 10 through June 24, 1985, and in accordance with the General Policy and Procedures for NRC Enforcement Actions (10 CFR Part 2, Appendix C), the following violation was identified:

Technical Specification 3.7.10.3 states, in part, "The following Halon Systems shall be operable (the systems specified includes the following:)

<u>Building</u>	<u>Elevation</u>	<u>Area Protected</u>
Auxiliary	2026	Load center and M.G. SETS Room *(1403)

*Areas containing redundant systems or components which could be damaged."

Action: "a." states, in part, "With one or more of the above required Halon Systems inoperable, within one hour establish a continuous fire watch with backup fire suppression equipment for those areas in which redundant systems or components could be damaged."


Contrary to the above, a continuous fire watch was not established when Door No. 14031 for Room 1403 was open from February 8 to February 10, 1985, which rendered the Halon system for the room inoperable.

This is a Severity Level IV violation (Supplement 1).

The inspection showed that licensee action had been taken to correct the violation and to prevent recurrence. Consequently, no reply to this violation is required and we have no further questions regarding this item.

JUL 24 1985

Dated _____


N. J. Chrissotimos, Chief
Reactor Projects Branch 2

8507260510 850724
PDR ADOCK 05000483
Q PDR