

## LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Kewaunee Nuclear Power Plant										DOCKET NUMBER (2) 0 5 0 0 0 3 0 5					PAGE (3) 1 OF 0 1	
TITLE (4) Inadequate Implementation of Administrative Controls																
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)						
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)			
0 6	1 5	8 5	8 5	0 1 4	0 0 0 7	1 5	8 5						0 5 0 0 0			
														0 5 0 0 0		
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)														
N		20.402(b)				20.406(c)				50.73(a)(2)(iv)				73.71(b)		
POWER LEVEL (10)		20.406(a)(1)(i)				50.36(a)(1)				50.73(a)(2)(v)				73.71(c)		
1 0 0		20.406(a)(1)(ii)				50.36(a)(2)				50.73(a)(2)(vii)				OTHER (Specify in Abstract below and in Text, NRC Form 366A)		
		20.406(a)(1)(iii)				X 50.73(a)(2)(ii)				50.73(a)(2)(viii)(A)						
		20.406(a)(1)(iv)				50.73(a)(2)(iii)				50.73(a)(2)(viii)(B)						
		20.406(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(ix)						
LICENSEE CONTACT FOR THIS LER (12)																
NAME Sherry L. Bernhoft - Plant Technical Support Engineer										TELEPHONE NUMBER						
										AREA CODE 4 1 4 3 8 8 - 2 5 6 0						
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS							
SUPPLEMENTAL REPORT EXPECTED (14)										EXPECTED SUBMISSION DATE (15)			MONTH	DAY	YEAR	
YES (If yes, complete EXPECTED SUBMISSION DATE)										X NO						
ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single space typewritten lines) (16)																
<p>At 1730 on June 15, 1985, the Auxiliary Operator found the concrete block, which prevents access to the spent resin storage tank (WB) room, removed. The entry way was barricaded and a high radiation area sign posted. The tank was reading 1 to 4 Rem/Hr on contact with a general area background reading of 0.2 to 0.3 Rem/Hr. This was a violation of Technical Specification 6.13.1.b, which requires that each High Radiation Area, where the intensity of radiation is greater than 1 Rem/Hr, be maintained under the administrative control of the Shift Supervisor. The block had been removed on the morning of June 13 to allow design change and maintenance work on the tank.</p> <p>During the day shifts of June 13 and June 14, access was positively controlled by radiation protection personnel providing coverage in the area. During the associated backshifts, when there is minimal activity in the Auxiliary Building, the area was barricaded and posted as a high radiation area. On June 15 when the operations personnel discovered the situation, the on-shift radiation protection technician was directed to survey the area, and the concrete block was returned to its proper location with the locking device secured at 1835.</p> <p>To prevent recurrence, Technical Specification requirements for securing high radiation areas were discussed during the weekly Radiation Protection staff meeting on June 18, 1985.</p>																
8507260627 850715 PDR ADOCK 05000305 S PDR																

LE-22  
11

## WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 700, Green Bay, Wisconsin 54305

July 15, 1985

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Docket 50-305  
Operating License DPR-43  
Kewaunee Nuclear Power Plant  
Reportable Occurrence 85-014-00

In accordance with the requirements of 10 CFR 50.73, "Licensee Event Report System", the attached Licensee Event Report for reportable occurrence 85-014-00 is being submitted.

Very truly yours,

A handwritten signature in dark ink, appearing to read "DCH".

D. C. Hintz  
Manager - Nuclear Power

GWH/js  
Attach.

cc - INPO Records Center  
Suite 1500, 1100 Circle 75 Parkway  
Atlanta, GA 30339  
Mr. Robert Nelson, NRC Resident Inspector  
RR #1, Box 999, Kewaunee, WI 54216  
Mr. S. A. Varga, Chief  
US NRC, Washington, DC 20555  
Mr. J. G. Keppler, Regional Administrator  
Region III, US NRC, 799 Roosevelt Road  
Glen Ellyn, IL 60137  
Ms. N. A. Nicholson  
Region III, US NRC, 799 Roosevelt Road  
Glen Ellyn, IL 60137

IE22  
1/1