



# SAFEGUARDS INFORMATION

UNITED STATES  
NUCLEAR REGULATORY COMMISSION

REGION II  
101 MARIETTA STREET, N.W.  
ATLANTA, GEORGIA 30303

JAN 10 1985

Report No. 50-302/84-23

Licensee: Florida Power Corporation  
P. O. Box 14042  
St. Petersburg, FL 33733

Docket No. 50-302

License No. DPR-72

Facility Name: Crystal River 3

Inspection Date: August 12-16, 1984

Inspector: D. E. Moore  
D. E. Moore, Physical Security Inspector

1/2/85  
Date Signed

Approved by: D. R. McGuire  
D. R. McGuire, Chief, Physical Security Section  
Nuclear Materials Safety and Safeguards Branch  
Division of Radiation Safety and Safeguards

1/2/85  
Date Signed

## SUMMARY

Scope: This routine unannounced inspection entailed 32 inspector-hours on site (6 hours on backshift) inspecting: security organization personnel/response; testing and maintenance; physical barriers-vital areas; security system power supply; access control-personnel/packages/vehicles; detection aids-vital areas; and independent inspection effort. Additionally, 6 hours were devoted to allegation followup concerning another NRC licensed facility.

Results: Two violations of regulatory requirements were identified:

Failure to implement and fully maintain provisions of the approved physical security plan concerning the protection of vital equipment.

Inadequate vital area physical barrier.

8507260672 850110  
PDR ADOCK 05000302  
Q PDR

ENCLOSURE CONTAINS  
SAFEGUARDS INFORMATION.  
UPON SEPARATION THIS  
PAGE IS DECONTROLLED.

SAFEGUARDS INFORMATION