

MAY 29 1985

Docket No. 50-341

The Detroit Edison Company
ATTN: Wayne H. Jens
Vice President
Nuclear Operations
6400 North Dixie Highway
Newport, MI 48166

Gentlemen:

This refers to the routine safety inspection conducted by Mr. R. Hasse of this office on May 13-22, 1985, of activities at Fermi Nuclear Power Plant authorized by NRC Operating License NPF-33 and to the discussion of our findings with Mr. E. Griffing and others of your staff at the conclusion of the inspection.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

While no violations of NRC requirements were identified during the course of this inspection, we do request that you respond to two unresolved items identified in the attached report. Both of these items are related to your preventive maintenance (PM) program. One involves the currently low rate of completion of scheduled PM tasks and the other the potential for applying resources to lower priority PM tasks when higher priority tasks are overdue. We believe these issues are significant and warrant particular attention. Your response is requested within 30 days of receipt of this letter.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosure will be placed in the NRC Public Document Room.

The response directed by this letter is not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

"Original Signed by R. L. Spessard"

R. L. Spessard, Director
Division of Reactor Safety

Enclosure: Inspection Report
No. 50-341/85026

8506040198 850529
PDR ADOCK 05000341
Q PDR

1E01.11

The Detroit Edison Company

2

MAY 29 1985

cc w/enclosure:

L. P. Bregni, Licensing
Engineer

P. A. Marquardt, Corporate
Legal Department

DMB/Document Control Desk (RIDS)

Resident Inspector, RIII

Ronald Callen, Michigan

Public Service Commission

Harry H. Voigt, Esq.

Nuclear Facilities and

Environmental Monitoring

Section

RIII

[Signature]
Hasse/lc
5/29/85

RIII

[Signature]
Jones

RIII

[Signature] 5/29
Hawkins

RIII

[Signature]
Chrisotimos

RIII

[Signature]
Reyes

R ☐
S. JESSAAD
5/29