



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

July 2, 1979

MEMORANDUM FOR: B. H. Grier, Director, Region I  
J. P. O'Reilly, Director, Region II  
J. G. Keppler, Director, Region III  
K. V. Seyfrit, Director, Region IV  
R. H. Engelken, Director, Region V

FROM: N. C. Moseley, Director, Division of Reactor Operations  
Inspection, Office of Inspection and Enforcement

SUBJECT: IE BULLETIN NO. 79-14 - SEISMIC ANALYSES FOR AS-BUILT  
SAFETY-RELATED PIPING SYSTEMS

The subject IE Bulletin should be dispatched for action today, to all power reactor facilities with an operating license or a construction permit.

The text of the Bulletin and draft letter to licensees are enclosed for this purpose.

N. C. Moseley, Director  
Division of Reactor Operations Inspection  
Office of Inspection and Enforcement

Enclosure:  
IE Bulletin 79-14

CONTACTS: R. Woodruff  
H. Wong  
49-28180

A-2

(Draft letter to all facilities with an operating license or a construction permit)

IE Bulletin No. 79-14

Addressee:

The enclosed Bulletin 79-14 is forwarded to you for action. Written responses are required. If you desire additional information regarding this matter, please contact this office.

Sincerely,

Signature  
(Regional Director)

Enclosure:  
IE Bulletin No. 79-14

Warrick & Danielson, Tele, 7/10/79

---

Re IEB 79-14

1. Northern States had asked for guidance re pipes  $< 2\frac{1}{2}$ " based on IEB 79-02 scope.
2. Intent of 79-14 is to look at all S-R piping which was subjected to seismic analysis. This includes some pipe  $< 2$ ".

6/14/79

MEMO TO FILES:

Ed asked that I prepare a bulletin that would result in assurance that seismic analyses conform to as-built plants. Areas of concern include embedments, valve weights, pipe supports, pipe schedule, etc. Documents that pertain are IEB 79-02, 04, and 07; orders; and correspondence re Stone and Webster's analytical technique. Wong was assigned but hadn't started. He will provide on 6/18 documents in his possession.

John Fair in Noonan's branch provided input for IEB 79-07, 02,  
Bill Russell is coordinating seismic issues.

A-1