

FILE COPY

JUN 20 1985

Cleveland Electric Illuminating  
Company  
ATTN: Murray R. Edelman  
Vice President - Nuclear Group  
55 Public Square  
Cleveland, OH 44101

Gentlemen:

Enclosed is Amendment No. 02 to NRC License Number 34-07043-05 which authorizes use of a 100 millicuries cesium-137 source for calibration of post-accident high range area radiation monitors.

You are reminded that you are subject to the requirements set forth in 10 CFR Part 20 with respect to use and storage of the sealed source.

In view of this amendment, please review your license carefully to assure that you understand and are in compliance with the terms and conditions contained therein. If you have questions, please contact our office by dialing (312) 790-5625.

Sincerely,

Original Signed By  
B. J. Holt  
Materials Licensing Section

Enclosure: Amendment No. 02

RIII

Holt/as  
06/18/85

8507150092 850620  
REG3 LIC30  
34-07043-05 PDR

# CONVERSATION RECORD

TIME

DATE

TYPE

☐ VISIT

☐ CONFERENCE

☐ TELEPHONE

☐ INCOMING

☐ OUTGOING

ROUTING

NAME/SYMBOL

INT

Location of Visit/Conference:

NAME OF PERSON(S) CONTACTED OR IN CONTACT WITH YOU

ORGANIZATION (Office, dept., bureau, etc.)

TELEPHONE NO:

SUBJECT

*Note to File:*

*Control No. 78825*

SUMMARY

*This licensee did not specifically answer the questions raised in our phone discussion of 5/14/85, however, it appears that they have specific procedures for handling radioactive material. (See letter dated June 4, 1985 with attached procedures). These procedures are not referenced in the tie-down condition because 1) they do not relate specifically to the amendment in question or 2) I don't agree with some of the action levels used, eg. 100 dpm/100cm<sup>2</sup> for alpha contamination, 300 cpm bkg for monitoring personnel*

ACTION REQUIRED

*None*

NAME OF PERSON DOCUMENTING CONVERSATION

SIGNATURE

DATE

*[Signature]*

*6/14/85*

ACTION TAKEN

SIGNATURE

TITLE

DATE

Contamination. The licensee informed me that these procedures had been reviewed by Don Miller (ORSS). I discussed them with him and he said that he would take a look at them again. He also assured me that the licensee will be able to handle a bare 100 mCi Cs-137 source safely.