

MAY 31 1985

Docket No. 50-295

Docket No. 50-304

Commonwealth Edison Company

ATTN: Mr. Cordell Reed

Vice President

Post Office Box 767

Chicago, IL 60690

Gentlemen:

This is to acknowledge receipt of Revision 4 to the Zion Annex to the Generating Stations Emergency Plan (GSEP), dated December 1984, which was received by our office in May, 1985.

We have reviewed the changes to the Annex and determined that they are consistent with the requirements of 10 CFR 50.54(q) and do not decrease the effectiveness of the emergency plan. These changes are, therefore, acceptable.

Please be reminded that 10 CFR 50.54(q) requires NRC approval of any changes to your emergency plans which may decrease their effectiveness. However if your safety review assures no decrease in emergency preparedness effectiveness, then such changes may be made and implemented without prior NRC approval. In all cases, you must furnish copies of each proposed change to the NRC in accordance with 10 CFR 50.54(q). Also any changes to the Emergency Plan Implementing Procedures should be made in accordance with the requirements of 10 CFR Part 50, Appendix E, Section V.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter will be placed in the NRC's Public Document Room.

IE35
1/0


Commonwealth Edison Company

2

MAY 31 1985

Should you have any questions regarding this letter, please contact Mr. T. Ploski of my staff at (312) 790-5529.

Sincerely,



C. J. Paperiello, Chief
Emergency Preparedness and
Radiological Protection Branch

cc: D. L. Farrar, Director
of Nuclear Licensing
K. L. Graesser, Plant Manager
Jan Norris, Project Manager, NRR
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Phyllis Dunton, Attorney
General's Office, Environmental
Control Division
Mayor, City of Zion
D. Matthews, EPB, OIE
W. Weaver, FEMA, Region V
L. D. Butterfield, Technical
Services Manager, CECO

RIII

Ploski/pg
05/30/85

RIII

Wright

RIII

Phillips

RIII

Paperiello