

ATTACHMENT 4

NRC DOCKET 50-321

OPERATING LICENSE DPR-57

EDWIN I. HATCH NUCLEAR PLANT UNIT 1

REQUEST TO REVISE TECHNICAL SPECIFICATIONS:

PROPOSED CHANGES TO SPECIAL REPORTING REQUIREMENTS

The proposed change to Technical Specifications (Appendix A to Operating License DPR-57) would be incorporated as follows:

Remove Page

6-19

Insert Page

6-19

8506040441 850520
PDR ADOCK 05000321
PDR

TABLE 6.9.2-1

SPECIAL REPORTING REQUIREMENTS

<u>Area</u>	<u>Tech Spec Reference</u>	<u>Submittal Date</u>
a. Primary Containment Leak Rate Tests (1)	4.7.A	Within 3 months following conduct of test
b. In-Service Inspection Evaluation	4.6.K	5 years (2)
c. Reactor Coolant Radioactivity in excess of specified limits	4.6.F	Within 30 days of the occurrence

Notes:

1. Each integrated leak rate test of the primary containment shall be the subject of a summary technical report including results of the local leak rate tests since the last report. The report as described in the 10 CFR Part 50, Appendix J, "Primary Reactor Containment Leakage Testing for Water-Cooled Power Reactors, " shall include data, analysis, and interpretations of the results which demonstrate compliance in meeting the specified leak rate limits.
2. The report shall be submitted within the period of time listed based on the commercial service date as the starting period