

NAME OF REGISTERED	Robert J. Druga, Mgr.-Technical Services	412/643-5308
--------------------	--	--------------

8507150200 850624  
PDR ADOCK 05000334  
S PDR

NRC USE ONLY

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (Continued)

transmitters. This evaluation determined that the instrument inaccuracies were sufficient to cause inappropriate operator actions. As a result, the Emergency Operating Procedures were appropriately revised to account for the instrument inaccuracies. These revisions were in effect until the transmitters were replaced. The new transmitters conform to all required specifications. There has been no danger to the health and safety of the general public.

Attachment to LER 82-010/01T-1  
Beaver Valley Power Station  
Duquesne Light Company  
Docket No. 50-334

On 4/8/82, Duquesne Light Company received notification from Westinghouse on a potential unreviewed safety question as defined in 10 CFR 50.59 on RCS wide range pressure instrumentation. The instrumentation in question has been replaced with qualified instrumentation from a different vendor and is currently being evaluated by engineering personnel for possible changes to the Emergency Operating Procedures.



**Duquesne Light**

Nuclear Group  
P.O. Box 4  
Shippingport, PA 15077-0004

Telephone (412) 393-6000

June 24, 1985  
ND1SS1:2384

Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334, License No. DPR-66  
LER 82-010/01T-1


Dr. Thomas E. Murley  
Regional Administrator  
United States Nuclear Regulatory Commission  
Region I  
Park Avenue  
King of Prussia, PA 19046

Gentlemen:

In accordance with Appendix A, Beaver Valley Technical Specifications the following Licensee Event Report is submitted:

LER 82-010/01T-1, Technical Specification 6.9.1.8.e, Administrative Controls.

Very truly yours,

  
Wm. S. Lacey  
Plant Manager

ind

Attachment

1E:22  
11

T. E. Murley  
March 15, 1985  
ND1SS1:2384  
Page two

cc: Director of Management & Program Analysis  
United States Nuclear Regulatory Commission  
Washington, D.C. 20555

C. A. Roteck, Ohio Edison

Director, Office of Inspection and Enforcement Headquarters  
United States Nuclear Regulatory Commission  
Washington, D.C. 20555

Mr. Peter Tam, BVPS Licensing Project Manager  
United States Nuclear Regulatory Commission  
Washington, D.C. 20555

W. Troskoski, Nuclear Regulatory Commission, BVPS Site Inspector

Mr. Alex Timme, CAPCO Nuclear Projects Coordinator, Toledo Edison

INPO Records Center  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, GA 30339

G. E. Muckle, Factory Mutual Engineering, Pittsburgh

Mr. J. A. Triggiani, Operating Plant Projects Manager  
Mid Atlantic Area  
Westinghouse Electric Corporation  
Nuclear Services Integration Division  
Box 2728  
Pittsburgh, PA 15230

American Nuclear Insurers  
c/o Dottie Sherman, ANI Library  
The Exchange Suite 245  
270 Farmington Avenue  
Farmington, CN 06032