

October 18, 1996

John Eichling, Ph.D.
 Radiation Safety Officer
 Washington University
 School of Medicine
 Campus Box 8131
 660 S. Euclid Avenue
 St. Louis, MO 63110-1093

SUBJECT: NOTICE OF VIOLATION DATED AUGUST 29, 1996

Dear Dr. Eichling:

This acknowledges receipt of your letter dated September 27, 1996, in response to our letter dated August 29, 1996, transmitting a Notice of Violation. Our letter also identified an area of concern for lack of contingency planning and use of appropriate facilities and equipment to trap and control accidental releases of iodine-131 in the nuclear pharmacy. An additional concern was identified for lack of continuous air monitoring of the iodine-131 concentration in the nuclear pharmacy restricted area and in the hood effluent.

We have reviewed your measures to address these concerns, which appear to be adequate, and have no further questions at this time. These actions will be examined during a future inspection.

Sincerely,

Original Signed by Roy J. Caniano

Cynthia D. Pederson, Director
 Division of Nuclear Materials Safety

License No.: 24-00167-11
 Docket No.: 030-02271

.bcc w/ltr dtd 09/27/96: PUBLIC
 B. Burgess, EICS

9610220045 961018
 PDR ADDCK 03002271
 C PDR

DOCUMENT NAME: G:\LTRS2LIC\MTLS\030\03002271.962

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	DNMS/RIII	C	DNMS/RIII	E	DNMS/RIII				
NAME	T. Young <i>ty</i>		M. Phillips <i>MP</i>		C. Pederson <i>CP</i>				
DATE	10/17/96		10/17/96		10/17/96				

OFFICIAL RECORD COPY

9610220045

IE07