



SAFEGUARDS INFORMATION

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA STREET, N.W.
ATLANTA, GEORGIA 30323

APR 9 1985

Report No. 50-395/85-14

Licensee: South Carolina Electric and Gas Company
Columbia, South Carolina 29218

Docket No. 50-395

License No. NPF-12

Facility Name: V. C. Summer Nuclear Station

Inspection Date: March 25-29, 1985

Inspector: A. Tillman
A. Tillman, Physical Security Inspector

4/9/85
Date Signed

Approved by: D. R. McGuire
D. R. McGuire, Chief, Physical Security Section
Nuclear Materials Safety and Safeguards Branch
Division of Radiation Safety and Safeguards

4/9/85
Date Signed

SUMMARY

Scope: This routine, unannounced inspection involved 37 inspector-hours onsite (four hours backshift) inspecting: Security Plan and Implementing Procedures; Management Effectiveness - Security Program; Security Program Audit; Locks, Keys, and Combinations; Physical Barriers - Protected Area; Security System Power Supply; Compensatory Measures; Access Control - Personnel; Access Control - Packages; Access Control - Vehicles; Communications; and Personnel Training and Qualification - General Requirements.

Results: No violations or deviations were identified in 11 of the 12 areas inspected. One apparent violation was found in the area of Access Control - Personnel. (The Security Officer responsible for the last access control function was not isolated in a bullet resisting structure.)

8506040661 850409
PDR ADDCK 05000395
Q PDR

ENCLOSURE CONTAINS
SAFEGUARDS INFORMATION
UPON SEPARATION THIS
PAGE IS DECONTROLLED.

SAFEGUARDS INFORMATION