



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

June 26, 1985

Docket No. 50-346

Toledo Edison Company  
ATTN: Mr. Richard P. Crouse  
Vice President, Nuclear  
Edison Plaza  
300 Madison Avenue  
Toledo, Ohio 43652

Gentlemen:

Enclosed is the report of the inspection performed at Davis-Besse by Messrs. E. T. Baker and J. J. Petrosino, and Ms. N. J. Miegel of the Vendor Program Branch on March 11-15, 1985. The purpose of the inspection was to determine if technical information regarding factory-recommended maintenance and operation related to emergency diesel generators, reactor trip breakers, auxiliary feedwater steam turbine, DC battery racks, Pacific Scientific Snubbers, and Ruskin Fire dampers was being reviewed and implemented effectively. The inspectors reviewed documents and activities authorized under the provisions of NRC License No. NPF-3, and discussed their findings with the plant staff members identified in Report Section 1, Details. The findings demonstrate a weakness in evaluation and implementation of manufacturers' recommendations and a failure to communicate with the manufacturers prior to making design changes.

The Inspection Report contains one finding related to reviewing, evaluating, and implementing vendor supplied documentation that may result in enforcement action. Resolution of the Potential Enforcement Finding will be handled by the NRC Region III office. Further, there are two Unresolved Items and one Open Item that require additional information before further action (if any) can be taken. NRC Region III will handle resolution of these items.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosed Inspection Report will be placed in the NRC Public Document Room.

The responses directed by this letter are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

FOR CS PROCESSING

Original document not available to ~~the~~

Certified by Sherry M. Quader

8507150547 850626  
PDR ADOCK 05000346  
G PDR

June 26, 1985

Should you have any questions concerning this matter, we would be pleased to discuss them with you.

Sincerely,

ORIGINAL SIGNED BY:  
GARY G. ZECH

Gary G. Zech, Chief  
Vendor Program Branch  
Division of Quality Assurance, Vendor  
and Technical Training Center Programs  
Office of Inspection and Enforcement

Enclosure:  
Inspection Report No. 50-346-85-017

DISTRIBUTION:

DCS → PDR  
VPB Reading  
DQAVT Reading  
RVollmer  
GHolahan, NRR  
EMerschhoff  
EBaker  
JPetrosino  
NMiegel

\*SEE PREVIOUS PAGE FOR CONCURRENCE.

VPB: DQAVT*	VPB: DQAVT*	VPB: DQAVT*
EBaker: sam	NMiegel	JPetrosino
5/13/85	5/13/85	5/16/85

SC/VPB: DQAVT*
EMerschhoff
5/16/85

BB  
VPB: DQAVT  
GGZech  
6/11/85

9  
DTR: DQAVT  
BKGrimes  
6/18/85