

**Florida
Power**
CORPORATION

June 28, 1985
3F0685-29

Ms. Brenda Mozafari, Project Manager
Operating Reactor Branch #4
Division of Licensing
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Bethesda, MD 20014

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
Technical Specification Change Request No. 122, Supplement 2

Dear Ms. Mozafari:

Florida Power Corporation (FPC) withdraws the change to item 6.a, Table 3.3-5, page 3/4 3-17 submitted to you on January 23, 1985 and supplemented on June 6, 1985, as it appears that the change was overly conservative. FPC has a proposal from Babcock & Wilcox (B&W) to clarify safety analysis assumptions. As part of this task, we expect to receive an evaluation of the response time for main feedwater isolation. If this evaluation shows that this response time should be changed, we will submit an amendment request to reflect the appropriate response time. We will keep the staff informed of the schedule and status of the B&W evaluation.

In general, change request No. 122 adds surveillance and operability requirements to support the new Emergency Feedwater Initiation and Control (EFIC) system. However, change request No. 122 (submitted on January 23, 1985) does contain two changes which were included for clarity and are not directly related to the EFIC system. These are:

- 1) On Table 3.3-10, under "Minimum Channels Operable", the zero's were revised to be "N/A" to clarify the requirement. Additionally, the notation in instruments 9. and 18. designating primary and secondary EFW flow indicators was removed for clarity.

8507150588 850628
PDR ADDCK 05000302
P PDR


Handwritten: A-001
11/1

June 28, 1985
3F0685-29
Page 2

- 2) On page 3/4 7-5, surveillance requirement C. was added with a footnote regarding implementation. The surveillance requirement was added at the staff's request in an NRC to FPC letter dated May 1, 1984.

FPC will not be utilizing the steam generator overfill termination feature of the EFIC system. Due to OTSG fouling, we may be operating at inventory levels close to or equivalent to the overfill setpoint. This could cause spurious main feedwater isolations and possibly induce unwanted feedwater transients.

Sincerely,

A handwritten signature in cursive script, appearing to read "G. R. Westafer".

G. R. Westafer
Manager, Nuclear Operations
Licensing and Fuel Management


PGH/feb

Enclosure

STATE OF FLORIDA


COUNTY OF PINELLAS

G. R. Westafer states that he is the Manager, Nuclear Operations Licensing and Fuel Management for Florida Power Corporation; that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission the information attached hereto; and that all such statements made and matters set forth therein are true and correct to the best of his knowledge, information, and belief.



G. R. Westafer
Manager, Nuclear Operations
Licensing and Fuel Management

Subscribed and sworn to before me, a Notary Public in and for the State and County above named, this 28th day of June, 1985.



Notary Public

Notary Public, State of Florida at Large,

My Commission Expires: November 12, 1986

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF)

FLORIDA POWER CORPORATION)

DOCKET No. 50-302

CERTIFICATE OF SERVICE


G. R. Westafer deposes and says that the following has been served on the Designated State Representative and the Chief Executive of Citrus County, Florida, by deposit in the United States mail, addressed as follows:

Chairman,
Board of County Commissioners
of Citrus County
Citrus County Courthouse
Inverness, FL 32650

Administrator
Radiological Health Services
Department of Health and
Rehabilitative Services
1323 Winewood Blvd.
Tallahassee, FL 32301


A copy of Technical Specification Change Request No. 122 requesting amendment to Appendix A of Operating Licensing No. DPR-72.

FLORIDA POWER CORPORATION



G. R. Westafer
Manager, Nuclear Operations
Licensing and Fuel Management

SWORN TO AND SUBSCRIBED BEFORE ME THIS 28th DAY OF JUNE 1985.


Notary Public

Notary Public, State of Florida at Large
My Commission Expires: November 12, 1986

(NOTARIAL SEAL)