GULF STATES UTILITIES COMPANY

RIVER BEND STATION POST OFFICE BOX 220 ST. FRANCISVILLE, LOUISIANA 70775

AREA CODE 504 635-6094 346-8651

July 19, 1985
RBG- 21,568
File No. G9.5

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Denton:

River Bend Station - Unit 1
Docket No. 50-458

Enclosed for your review is Gulf States Utilities Company proposed revisions to the River Bend Station Technical Specifications. The changes identified in Enclosure 1 conform to the information contained in the Final Safety Analysis Report.

Sincerely,

J. E. Booker

J. E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

JEB/DWW/JEP/je

Enclosure (1)

8507290310 850719
PDR ADOCK 05000458
A PDR

B001
1/1

ENCLOSURE 1

Changes for Technical Specification 3/4.3.2

Isolation Actuation Instrumentation

Technical Modifications

Table 3.3.2-1

1. - Item 7, change valve groups to: "1 (ℓ), 5, 6, 7, 8, 11, 12, 13, 14, 15, 16."

   Delete valve group 10 because they do not isolate on the manual initiation.

   Add footnote (ℓ) to valve group 1 to show the design of one of the group 1 valves does not isolate on the manual initiation.

2. - Add footnote (ℓ) stating: "Valve 1E22*MOVF023 does not isolate on the manual initiation."