

May 30, 1985

Docket No. 50-245  
LS05-85-05-042

Northeast Nuclear Energy Company  
ATTN: Mr. John Opeka  
Senior Vice President - Nuclear  
Engineering and Operations  
Post Office Box 270  
Hartford, Connecticut 06141

Dear Mr. Opeka:

Subject: Continuous Containment Leak Rate Monitoring, Millstone Nuclear  
Power Station, Unit No. 1

In your letter W. G. Counsil to J. A. Zwolinski dated March 19, 1985, you indicated your commitment to install a modification at the upcoming refueling outage with instrumentation necessary to allow the continuous monitoring of containment leak rate. You also requested that the staff take no further action on previous requests to delete Technical Specification 4.7.A.3.g regarding continuous containment leak rate monitoring.

The letter acknowledges your commitment to install continuous containment leak rate monitoring capability and no further staff action will be taken on your previous requests to delete Technical Specification 4.7.A.3.g.

Sincerely,

Original signed by:

John A. Zwolinski, Chief  
Operating Reactors Branch No. 5  
Division of Licensing

cc: See next page

DISTRIBUTION

Docket File	HThompson
ORB#5 Reading	OELD
NRC PDR	EJordan
Local NRC PDR	BGrimes
CJamerson	JPartlow
JShea	ACRS (10)
JZwolinski	JKudrick

8506050400 850530  
PDR ADOCK 05000245  
P PDR

DL:ORB#5  
CJamerson  
05/30/85

DL:ORB#5  
JShea:tm  
05/30/85

DL:ORB#5  
for JZwolinski  
05/30/85

SE01  
1/0 EX/27

Mr. John F. Opeka  
Northeast Nuclear Energy Company

Millstone Nuclear Power Station  
Unit No. 1

cc  
Gerald Garfield, Esquire  
Day, Berry & Howard  
Counselors at Law  
City Place  
Hartford, Connecticut 06103-3499

Kevin McCarthy, Director  
Radiation Control Unit  
Department of Environmental  
Protection  
State Office Building  
Hartford, Connecticut 06106

Edward J. Mroczka  
Vice President, Nuclear Operations  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141

State of Connecticut  
Office of Policy and Management  
ATTN: Under Secretary Energy  
Division  
80 Washington Street  
Hartford, Connecticut 06106

Regional Administrator  
Nuclear Regulatory Commission, Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Northeast Nuclear Energy Company  
ATTN: Superintendent  
Millstone Nuclear Power Station  
P. O. Box 128  
Waterford, Connecticut 06358

Resident Inspector  
c/o U.S. NRC  
Millstone Nuclear Power Station  
P. O. Box 811  
Niantic, Connecticut 06357

First Selectman of the Town  
of Waterford  
Hall of Records  
200 Boston Post Road  
Waterford, Connecticut 06385