

U.S. Nuclear Regulatory Commission
LIC-96-0163

ATTACHMENT A

9610230264 961022
PDR ADDCK 05000285
P PDR

5.0 **ADMINISTRATIVE CONTROLS**

5.9.5 Core Operating Limits Report

- a. Core Operating Limits shall be established and documented in the Core Operating Limits Report (COLR) before each reload cycle or any remaining part of a reload cycle.
- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC as follows:
 1. OPPD-NA-8301-P-A, "Reload Core Analysis Methodology Overview" (Latest NRC approved revision as stated in the COLR).
 2. OPPD-NA-8302-P-A, "Neutronics Design Methods and Verification" (Latest NRC approved revision as stated in the COLR).
 3. OPPD-NA-8303-P-A, "Transient and Accident Methods and Verification" (Latest NRC approved revision as stated in the COLR).
 4. WCAP-12610, "VANTAGE + Fuel Assembly Report," June 1990 (Westinghouse Proprietary) as approved in the Safety Evaluation By The Office of Nuclear Reactor Regulation Related to Amendment No. _____ to Facility Operating License No. DPR-40, Omaha Public Power District, Fort Calhoun Station Unit No. 1, Docket No. 50-285, dated _____.
- c. The core operating limits shall be determined so that all applicable limits of the safety analysis are met. The Core Operating Limits Report, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Region IV Administrator and Senior Resident Inspector.