

GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

February 28, 1983.
5211-83-057


Mr. R. C. Haynes
Region I, Regional Administrator
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Dear Sir:

Three Mile Island Nuclear Station, Units 1 and 2 (TMI-1 and TMI-2)
Operating License Nos. DPR-50 and DPR-73
Docket Nos. 50-289 and 50-320
10 CFR 20.407 Personnel Exposure Report

Enclosed is the personnel monitoring report for TMI-1 and TMI-2 required by
10 CFR 20.407.

Sincerely,


H. D. Hukill
Director, TMI-1

HDH:JGB:vjf

Attachment

8506050474 841217
PDR FOIA
DETJEN84-780 PDR

DPR-50, B11
DPR-73THREE MILE ISLAND NUCLEAR STATION
STATISTICAL SUMMARY REPORT OF
PERSONNEL MONITORING INFORMATION
10 CFR 20
20.407

REPORT PERIOD: JANUARY 1, 1982 THROUGH DECEMBER 31, 1982

Estimated Whole Body Exposure Range (Rems)	Number of Individuals In Each Range
No Measurable Exposure	607
Exposure Less Than 0.1	1,033
0.1 to 0.25	288
0.25 to 0.5	197
0.5 to 0.75	124
0.75 to 1	122
1 to 2	269
2 to 3	77
3 to 4	11
4 to 5	2
5 to 6	0
6 to 7	0
7 to 8	0
8 to 9	0
9 to 10	0
10 to 11	0
11 to 12	0
More than 12	0

Total number of individuals monitored
by thermoluminescent dosimeter

2,730 R