



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555-0001

July 13, 1993

PDR

Docket No. 50-395

Mr. John L. Skolds, Vice President  
Nuclear Operations  
South Carolina Electric & Gas Company  
Virgil C. Summer Nuclear Station  
Post Office Box 88  
Jenkinsville, South Carolina 29065

Dear Mr. Skolds:

SUBJECT: RESPONSE TO BULLETIN 92-01, "FAILURE OF THERMO-LAG 330 FIRE BARRIER SYSTEM" - V. C. SUMMER NUCLEAR STATION, UNIT 1, (TAC NO. M83935)

By letters dated June 20, 1992, September 15, 1992, and February 22, 1993, South Carolina Electric & Gas Company responded to Bulletin 92-01 and Supplement 1 to the Bulletin. Your responses stated that compensatory measures consistent with the plant Technical Specifications have been implemented. You also provided a description of the options you are considering in the long-term to restore operability. These options include:

1. Review of current test data to verify adequacy of current barriers,
2. Receipt and review of new test documentation to upgrade present installations, and
3. Possible replacement of the Thermo-Lag 330.

We have reviewed your response and find it acceptable. Please inform us when all corrective actions have been completed.

Sincerely,

*George F. Wunder*

George F. Wunder, Project Manager  
Project Directorate II-1  
Division of Reactor Projects I/II  
Office of Nuclear Reactor Regulation

cc: See next page

9610240017 930713  
PDR ADOCK 05000395  
G PDR

LF03  
1/0  
Per Al Johnson