GULF STATES UTILITIES COMPANY

RIVER BEND STATION POST OFFICE BOX 220 ST. FRANCISVILLE, LOUISIANA 70775

AREA CODE 504 635-6094 346-8651

July 19, 1985
RBG- 21,569
File No. G9.5

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Denton:

River Bend Station - Unit 1
Docket No. 50-458

Enclosed for your review is Gulf States Utilities Company proposed revisions to the River Bend Station Technical Specifications. The changes identified in Enclosure 1 conform to the information contained in the Final Safety Analysis Report.

Sincerely,

J. E. Booker

J. E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

JEB/DWW/JEP/je

Enclosure (1)

8507290487 850719
PDR ADOCK 05000458
A PDR

B001
1/1

ENCLOSURE 1

Changes to Technical Specification 3/4.3.7.4
Remote Shutdown Monitoring Instrumentation and Controls

Item 18, RCIC Turbine Local Control Select Switch, on Table 3.3.7.4-2, should be labeled 1C61A-S11 and not 1E51-511. Section 7.4.1.4.2.a of the FSAR was revised in Amendment 20 to reflect this information.

Item 43, SSW Component Cooling Water Inlet MOV (1SWP*MOV510A, B), and Item 44, SSW Component Cooling Water Outlet MOV (1SWP*MOV504A, B) should be added to Table 3.3.4.4-2. Each item has one control in each control location, RSP1 and RSP2. These valves are the inlet and outlet to the reactor plant component cooling water system (RPCCW). The FSAR, Section 7.4.1.4.2.d, was revised in Amendment 21 to reflect the addition of Items 43 & 44.