

Georgia Power Company  
333 Piedmont Avenue  
Atlanta, Georgia 30308  
Telephone 404 526-6526

Mailing Address:  
Post Office Box 4545  
Atlanta, Georgia 30302

L. T. Gucwa  
Manager Nuclear Engineering  
and Chief Nuclear Engineer



NED-85-325  
1597N

June 24, 1985

Director of Nuclear Reactor Regulation  
Attention: Mr. John F. Stolz, Chief  
Operating Reactors Branch No. 4  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

NRC DOCKET 50-321  
OPERATING LICENSE DPR-57  
EDWIN I. HATCH NUCLEAR PLANT UNIT 1  
REQUEST TO REVISE TECHNICAL SPECIFICATIONS:  
EDITORIAL CHANGE TO CORRECT A TYPOGRAPHICAL ERROR  
IN TECHNICAL SPECIFICATION 4.5.D.2

Gentlemen:

In accordance with the provisions of 10 CFR 50.90 as required by 10 CFR 50.59(c)(1), Georgia Power Company hereby proposes a change to the Technical Specifications, Appendix A to Operating License DPR-57.

The proposed change is editorial in nature and would correct a typographical error in Technical Specification 4.5.D.2 (Page 3.5-7). This correction will replace text that was inadvertently deleted in retyping sheet 3.5-7 for the submittal to the NRC that resulted in Amendment 101. The typographical error is not associated with the revisions incorporated by Amendment 101.

Attachment 1 provides a detailed description of the proposed change and circumstances necessitating the change request.

Attachment 2 details the basis for our determination that the proposed change does not constitute an unreviewed safety question.

Attachment 3 details the basis for our determination that the proposed change does not involve significant hazards considerations.

Attachment 4 provides page change instructions for incorporating the proposed change.

The proposed changed Technical Specification page follows Attachment 4.

Payment of filing fee is enclosed.

8507160310 , 8506  
PDR ADOCK 05000321  
P PDR


Adol  
w/ check  
\$150.00  
#909496

Director of Nuclear Reactor Regulation  
Attention: Mr. John F. Stolz, Chief  
Operating Reactors Branch No. 4  
June 24, 1985  
Page Two


Pursuant to the requirements of 10 CFR 50.91, Mr. J. L. Ledbetter of the Environmental Protection Division of the Georgia Department of Natural Resources will be sent a copy of this letter and all applicable attachments.

J. T. Beckham, Jr. states that he is Vice President of Georgia Power Company and is authorized to execute this oath on behalf of Georgia Power Company, and that to the best of his knowledge and belief the facts set forth in this letter are true.

GEORGIA POWER COMPANY

By:   
J. T. Beckham, Jr.

Sworn to and subscribed before me this 24th day of June, 1985.

  
\_\_\_\_\_  
Notary Public, Georgia, State at Large      Notary Public  
My Commission Expires Aug. 26, 1986  
GDP/mb

Enclosure

xc: H. C. Nix, Jr.  
Senior Resident Inspector  
J. N. Grace, (NRC-Region II)  
J. L. Ledbetter

ATTACHMENT 1

NRC DOCKET 50-321  
OPERATING LICENSE DPR-57  
EDWIN I. HATCH NUCLEAR PLANT UNIT 1  
REQUEST TO REVISE TECHNICAL SPECIFICATIONS:  
EDITORIAL CHANGE TO CORRECT A TYPOGRAPHICAL ERROR  
IN TECHNICAL SPECIFICATION 4.5.D.2

The proposed change will replace text that was inadvertently deleted from Technical Specification 4.5.D.2. This specification presents the surveillance requirements for operation with an inoperable HPCI system. The first sentence of this specification should read that "When the HPCI system is inoperable, the ADS actuation logic, the RCIC system, the RHR system LPCI mode, and the CS system shall be demonstrated to be operable immediately." The words "... shall be demonstrated to be operable..." were inadvertently omitted from Technical Specification 4.5.D.2 during the retyping of the Technical Specifications for the GPC submittal (dated April 22, 1983) which resulted in Amendment 101. Amendment 101 addressed RCIC operation changes resulting from TMI modifications and did not affect Technical Specification 4.5.D.2. This correction to Technical Specification 4.5.D.2 is purely editorial and does not impact plant safety.

ATTACHMENT 2

NRC DOCKET 50-321  
OPERATING LICENSE DPR-57  
EDWIN I. HATCH NUCLEAR PLANT UNIT 1  
REQUEST TO REVISE TECHNICAL SPECIFICATIONS:  
EDITORIAL CHANGE TO CORRECT A TYPOGRAPHICAL ERROR  
IN TECHNICAL SPECIFICATION 4.5.D.2

Pursuant to 10 CFR 50.59, the Plant Review Board and Safety Review Board have reviewed the attached proposed amendment to the Plant Hatch Unit 1 Technical Specifications and have determined that implementation of the proposed amendment does not constitute an unreviewed safety question.

The proposed amendment does not increase the consequences or the probability of an accident or equipment malfunction important to safety previously evaluated in the FSAR. The change is purely editorial and has no effect on plant operation. The proposed change does not create a possibility for an accident or equipment malfunction of a different type than any evaluated previously in the FSAR since no new modes of plant operation are involved. The margin of safety, as defined in the Technical Specification, is not affected by this editorial change.

ATTACHMENT 3

NRC DOCKET 50-321  
OPERATING LICENSE DPR-57  
EDWIN I. HATCH NUCLEAR PLANT UNIT 1  
REQUEST TO REVISE TECHNICAL SPECIFICATIONS:  
EDITORIAL CHANGE TO CORRECT A TYPOGRAPHICAL ERROR  
IN TECHNICAL SPECIFICATION 4.5.D.2

Pursuant to 10 CFR 50.92, Georgia Power Company has evaluated the attached proposed amendment for Plant Hatch Unit 1 and has determined that its adoption would not involve a significant hazard. The basis for this determination is as follows:

This change is consistent with Item (i) of the "Examples of Amendments that are Considered Not Likely to Involve Significant Hazards Considerations" listed on page 14,870 of the Federal Register, April 6, 1983. Item (i) defines an administrative change to correct an error in the Technical Specifications, as a change involving no significant hazards considerations. The proposed change corrects an editorial error in the Technical Specifications, and thus clearly falls under Item (i).

ATTACHMENT 4

NRC DOCKET 50-321  
OPERATING LICENSE DPR-57  
EDWIN I. HATCH NUCLEAR PLANT UNIT 1  
REQUEST TO REVISE TECHNICAL SPECIFICATIONS:  
EDITORIAL CHANGE TO CORRECT A TYPOGRAPHICAL ERROR  
IN TECHNICAL SPECIFICATION 4.5.D.2

The proposed change to Technical Specifications (Appendix A to Operating License DPR-57) would be incorporated as follows:

Remove Page

3.5-7

Insert Page

3.5-7