

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)										DOCKET NUMBER (2)				PAGE (3)	
MONTICELLO NUCLEAR GENERATING PLANT										0 5 0 0 0 2 6 3				1 OF 0 2	

TITLE (4):
WRGM Trip Due to Power Loss

EVENT DATE (6)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)	
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)
06	03	85	85	012	00	07	03	85		05000

OPERATING MODE (9)		N	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 8: (Check one or more of the following) (11)						
POWER LEVEL (10)	100		20.402(b)		20.406(c)	<input checked="" type="checkbox"/>	50.73(a)(2)(iv)	<input type="checkbox"/>	73.71(b)
			20.406(a)(1)(i)		50.36(e)(1)	<input type="checkbox"/>	50.73(a)(2)(v)	<input type="checkbox"/>	73.71(e)
			20.406(a)(1)(ii)		50.36(c)(2)	<input type="checkbox"/>	50.73(a)(2)(vii)	<input type="checkbox"/>	OTHER (Specify in Abstract below and in Text, NRC Form 306A)
			20.406(a)(1)(iii)		50.73(a)(2)(i)	<input type="checkbox"/>	50.73(a)(2)(viii)(A)	<input type="checkbox"/>	
			20.406(a)(1)(iv)		50.73(a)(2)(ii)	<input type="checkbox"/>	50.73(a)(2)(viii)(B)	<input type="checkbox"/>	
			20.406(a)(1)(v)		50.73(a)(2)(iii)	<input type="checkbox"/>	50.73(a)(2)(x)	<input type="checkbox"/>	

LICENSEE CONTACT FOR THIS LER (12)		
NAME	AREA CODE	TELEPHONE NUMBER
Michael F. Hammer, I & C Engineer	612	219 51-5115

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)											
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	

SUPPLEMENTAL REPORT EXPECTED (14)		EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR
<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)	<input checked="" type="checkbox"/> NO				

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

A personnel error while performing a maintenance procedure on the channel A Reactor Building Vent Wide Range Gas Monitor resulted in a Reactor Building ventilation isolation and initiation of the Standby Gas Treatment System. The procedure will be revised.

8507160342 850703
PDR ADOCK 05000263
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104

EXPIRES: 8/31/85

FACILITY NAME (1) MONTICELLO	DOCKET NUMBER (2) 0 5 0 0 0 2 6 3	LER NUMBER (5)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
		8 5	— 0 1 2	— 0 0	0 2	OF	0 2

TEXT (If more space is required, use additional NRC Form 366A's) (17)

During power operation on June 3, 1985 at approximately 0704, a Reactor Building ventilation isolation (VA) and Standby Gas Treatment System, (BH) initiation occurred as a result of a personnel error while performing a preventative maintenance procedure on Channel A Reactor Building Vent Wide Range Gas Monitor. Contrary to the procedure, the licensed operator deenergized the monitor prior to installing the trip bypass jumpers, resulting in a high radiation signal upon deenergization of the normally energized monitor trip relays. The bypass jumpers were installed, the isolation reset, and the Reactor Building ventilation and Standby Gas Treatment System returned to normal. Work location conditions did not contribute to the error and it was not a cognitive error.

There was no effect on public health and safety.

There have been no previous similar reportable events.

Discussion of the event with the personnel resulted in a recommendation to revise the maintenance procedure to emphasize the required sequence of actions. This recommendation will be implemented.



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

July 3, 1985

U S Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DFR-22

WRGM Trip Due To Power Loss

The License Event Report for this occurrence is attached.

This event was reported via Emergency Notification System per 10 CFR Part 72
on June 3, 1985.

David Musolf
Manager - Nuclear Support Services

DMM/MMV/jk

c: Regional Administrator-III, NRC
NRR Project Manager, NRC
Resident Inspector, NRC
MPCA
Attn: J W Ferman

Attachment

IE22
11