



RECEIVED
NRC

Arizona Nuclear Power Project

P.O. BOX 52034 • PHOENIX, ARIZONA 85072-2034

1985 JUN 27 AM 10:26

June 20, 1985

ANPP-32860-TDS/TPS

REGION V ISE

U. S. Nuclear Regulatory Commission
Region V
1450 Maria Lane - Suite 210
Walnut Creek, CA 94596-5368

Attention: Mr. D. F. Kirsch, Acting Director
Division of Reactor Safety and Projects

Subject: Interim Report - DER 85-19
A 50.55(e) Potentially Reportable Deficiency Relating
To High Hydrazine Flow Rates
File: 85-019-026; D.4.33.2

Reference: Telephone Conversation between A. Hon and P. J. Coffin
on May 23, 1985.

Dear Sir:

The NRC was notified of a potentially reportable deficiency in the referenced telephone conversation. At that time, it was estimated that a determination of reportability would be made within thirty (30) days.

Due to the current correspondence with Combustion Engineering and extensive analysis involved an Interim Report is attached. It is now expected that this information will be finalized by July 26, 1985, at which time a complete report will be submitted.

Very truly yours,

E. E. Van Brunt, Jr.
Executive Vice President
Project Director

EEVB/TPS/plk

Attachment

cc: See Page Two

8507160366 850620
PDR ADDCK 05000528
S PDR

IE-27

cc: Richard DeYoung, Director
Office Of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

D. B. Karner
W. E. Ide
D. B. Fasnacht
A. C. Rogers
L. A. Souza
D. E. Fowler
T. D. Shriver
C. N. Russo
B. S. Kaplan
J. R. Bynum
J. M. Allen
D. Canady
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
H. D. Foster
D. R. Hawkinson
R. P. Zimmerman
M. L. Clyde
B. T. Parker
T. J. Bloom
D. N. Stover
J. D. Houchen
J. E. Kirby

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339

INTERIM REPORT - DER 85-19
POTENTIAL REPORTABLE DEFICIENCY
ARIZONA NUCLEAR POWER PROJECT
PVNGS UNIT 1, 2, 3

I. POTENTIAL PROBLEM

An evaluation by Combustion Engineering (C-E) concerning the Iodine Removal System performance indicates a potential for higher than design hydrazine flow rates.

II. APPROACH TO AND STATUS OF PROPOSED RESOLUTION

Bechtel Engineering is currently corresponding with C-E on this problem to determine reportability and technical justification for corrective action.

III. PROJECTED COMPLETION OF CORRECTIVE ACTION AND SUBMITTAL OF THE FINAL REPORT

The complete evaluation and Final Report are forecast to be completed by July 26, 1985.