



Entergy

Entergy Operations, Inc.

River Bend Station

5485 U. S. Highway 61

P.O. Box 220

St. Francisville, LA 70775

Tel 504 336 6225

Fax 504 635 5068

Rick J. King

Director

Nuclear Safety & Regulatory Affairs

October 08, 1996

U. S. Nuclear Regulatory Commission

Document Control Desk

Mail Stop P1-37

Washington, DC 20555

Subject: River Bend Station - Unit 1
Docket No. 50-458
Monthly Operating Report

File No. G9.5, G4.25

RBG-43288
RBF1-96-0380

Gentlemen:

In accordance with River Bend Station (RBS) Technical Specification 5.6.4, enclosed is the September, 1996 Monthly Operating Report for RBS.

Sincerely,

RJK/RMM/kvm
enclosure

9610240201 960930
PDR ADOCK 05000458
R PDR

040074

11
1024

Monthly Operating Report
October 08, 1996
RBG-43288
RBF1-96-0380
Page 2 of 2

cc: U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

NRC Senior Resident Inspector
P.O. Box 1050
St. Francisville, LA 70775

INPO Records Center
700 Galleria Parkway
Atlanta, GA 30339

Mr. Glen Dishong
PUCT
7800 Shoal Creek Blvd., Suite 400N
Austin, TX 78757

Dottie Sherman
American Nuclear Insurers
29 South Main Street
West Hartford, CN 06107

DOCKET NO. 50/458

RIVER BEND STATION UNIT 1

REPORT NO. R-96-09

DATE October 10, 1996

COMPLETED BY T. J. Bolke

TITLE Engineer III

TELEPHONE 504-346-8651 ext. 2940

MONTH September 1996

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1.	<u>946.5</u>
2.	<u>945.0</u>
3.	<u>944.0</u>
4.	<u>944.5</u>
5.	<u>944.2</u>
6.	<u>943.8</u>
7.	<u>943.0</u>
8.	<u>922.9</u>
9.	<u>942.0</u>
10.	<u>943.3</u>
11.	<u>944.7</u>
12.	<u>943.9</u>
13.	<u>924.4</u>
14.	<u>648.0</u>
15.	<u>866.2</u>
16.	<u>936.8</u>

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17.	<u>942.0</u>
18.	<u>946.2</u>
19.	<u>945.4</u>
20.	<u>945.0</u>
21.	<u>945.4</u>
22.	<u>948.5</u>
23.	<u>948.4</u>
24.	<u>947.8</u>
25.	<u>946.8</u>
26.	<u>943.8</u>
27.	<u>945.5</u>
28.	<u>952.8</u>
29.	<u>954.6</u>
30.	<u>955.5</u>

DOCKET NO. 50/458

RIVER BEND STATION UNIT 1

REPORT NO. R-96-09

DATE October 10, 1996

COMPLETED BY T. J. Bolke

TITLE Engineer III

TELEPHONE 504-346-8651 ext. 2940

PAGE 1 OF 2

OPERATING STATUS

1. REPORTING PERIOD: September, 1996 GROSS HOURS IN REPORTING PERIOD: 720

2. CURRENTLY AUTHORIZED POWER LEVEL (Mwt): 2894

MAX. DEPEND CAPACITY (MWe-Net): 936

DESIGN ELECTRICAL RATING (MWe-Net): 936

3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): N/A

4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMU- LATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL	<u>720.0</u>	<u>5286.7</u>	<u>70507.4</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>720.0</u>	<u>5184.9</u>	<u>67328.2</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>2,055,586</u>	<u>14,662,318</u>	<u>182,378,258</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>717,137</u>	<u>5,104,770</u>	<u>61,958,540</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>670,822</u>	<u>4,779,944</u>	<u>57,986,783</u>

DOCKET NO. 50/458

RIVER BEND STATION UNIT 1

REPORT NO. R-96-09

DATE October 10, 1996

COMPLETED BY T. J. Bolke

TITLE Engineer III

TELEPHONE 504-346-8651 ext. 2940

PAGE 2 OF 2

OPERATING STATUS

	THIS MONTH	YR TO DATE	CUMU- LATIVE
12. REACTOR SERVICE FACTOR	<u>100.0</u>	<u>80.4</u>	<u>74.3</u>
13 REACTOR AVAILABILITY FACTOR	<u>100.0</u>	<u>80.4</u>	<u>74.3</u>
14. UNIT SERVICE FACTOR	<u>100.0</u>	<u>78.9</u>	<u>72.2</u>
15. UNIT AVAILABILITY FACTOR	<u>100.0</u>	<u>78.9</u>	<u>72.2</u>
16. UNIT CAPACITY FACTOR (USING MDC)	<u>99.5</u>	<u>77.7</u>	<u>67.5</u>
17. UNIT CAPACITY FACTOR (USING DESIGN MWe)	<u>99.5</u>	<u>77.7</u>	<u>67.5</u>
18. UNIT FORCED OUTAGE RATE	<u>0.0</u>	<u>7.9</u>	<u>12.1</u>
19. SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, AND DURATION OF EACH):	None		
20. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):	N/A		

UNIT SHUTDOWNS AND POWER REDUCTIONS

NO.	DATE	TIME START OF OCCURRENCE	TIME RECOVER FROM OCCURRENCE	DURATION (HOURS)	TYPE NOTE (1)	REASON NOTE (2)	METHOD NOTE (3)	CORRECTIVE ACTION/ COMMENTS
-----	------	-----------------------------------	---------------------------------------	---------------------	------------------	--------------------	--------------------	--------------------------------

NONE

SUMMARY: No SRV challenges occurred during September.

NOTE (1) TYPE OF OCCURRENCE: ENTER CODE

F: FORCED

S: SCHEDULED

DOCKET NO. 50/458

RIVER BEND STATION UNIT 1

NOTE (2) REASON FOR OCCURRENCE: ENTER CODE

REPORT NO. R-96-09

- A: EQUIPMENT FAILURE (EXPLAIN IN CORRECTIVE ACTIONS/COMMENTS)
- B: MAINTENANCE OR TEST
- C: REFUELING
- D: REGULATORY RESTRICTION
- E: OPERATOR TRAINING AND LICENSE EXAMINATION
- F: ADMINISTRATIVE
- G: OPERATIONAL ERROR (EXPLAIN IN CORRECTIVE ACTIONS/COMMENTS)
- H: OTHER (EXPLAIN IN CORRECTIVE ACTIONS/COMMENTS)

REPORT MONTH September 1996


DATE October, 10 1996

NOTE (3) METHOD OF SHUTTING DOWN REACTOR OR REDUCING POWER: ENTER ONE

- 1. MANUAL
- 2. MANUAL SCRAM
- 3. AUTOMATIC SCRAM
- 4. OTHER (EXPLAIN IN CORRECTIVE ACTION/COMMENTS)

T. J. Bolke

COMPLETED BY



SIGNATURE

Engineer III

TITLE

TELEPHONE: 504-346-8651 ext. 2940