

APPENDIX A

NOTICE OF VIOLATION

Gulf States Utilities
River Bend, Unit 1

Docket: 50-458/85-33
Permit: CPPR-145

During an NRC inspection conducted on June 26, 1985, a violation of NRC requirements was identified. The violation involved the making of changes to quality assurance records. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1985), the violation is listed below:

1. Criterion XVII of Appendix B to 10 CFR Part 50 requires that inspection records identify the inspector, the results, and the acceptability.

Contrary to the above, the NRC inspector determined that the results for the general clearances attribute on Inspection Report Number P5400381 dated June 12, 1985, had been changed on June 13, 1985, from "not applicable" to "satisfactory" by a reviewer who neither had performed the inspection nor had any other inspection documentation to support the change.

The two supports identified in Inspection Report Number P5400381 were inspected by the NRC inspector and complied with the general clearance requirements of Construction Site Instruction Number 3.1.1, Revision 4.

A preliminary review by the licensee determined that a small percentage of other safety-related inspection reports contained similar changes.

This is a Severity Level V Violation. (Supplement II.E)

Pursuant to the provisions of 10 CFR 2.201, Gulf States Utilities is hereby required to submit to this office, within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) the reason for the violation if admitted; (2) the corrective steps which have been taken and the results achieved; (3) corrective steps which will be taken to avoid further violations; and (4) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated at Arlington, Texas
this 5th day of July, 1985.

8507160498 850712
PDR ADOCK 05000458
Q PDR