

ENCLOSURE 1

NOTICE OF VIOLATION

Entergy Operations, Inc.
Waterford Steam Electric Station, Unit 3

Docket No.: 50-382
License No.: NPF-38

During an NRC inspection conducted on July 21 through August 31, 1996, one violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," NUREG-1600, the violation is listed below:

Technical Specification 6.8.1.a requires, in part, that written procedures shall be maintained covering the applicable procedures recommended in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978. Appendix A, Section 9, requires that the licensee have maintenance procedures/written instructions appropriate to the circumstances.

Contrary to the above, on July 29, 1996, Work Authorization 01149346, which provided written instructions for adjusting the meter for component cooling water temperature control loop manual/automatic Station CC ITIC7070 B, was not appropriate to the circumstances in that the written instructions did not require returning the manual/automatic setpoint to its original state prior to returning the system to service and, as a result, Auxiliary Component Cooling Water Pump B inadvertently started automatically and caused a waterhammer in the system.

This is a Severity Level IV violation (Supplement I) (50-382/9611-03)

Pursuant to the provisions of 10 CFR 2.201, Entergy Operations, Inc. is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region IV, 611 Ryan Plaza Drive, Suite 400, Arlington, Texas 76011, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. Your response may reference or include previous docketed correspondence, if the correspondence adequately addresses the required response. If an adequate reply is not received within the time specified in this Notice, an order or a Demand for Information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Because your response will be placed in the NRC Public Document Room (PDR), to the extent possible, it should not include any personal privacy, proprietary, or safeguards information so that it can be placed in the PDR without redaction. However, if you find it necessary to include such information, you should clearly indicate the specific information

that you desire not to be placed in the PDR, and provide the legal basis to support your request for withholding the information from the public.

Dated at Arlington, Texas
this 20th day of Sept. 1996