

Docket Nos: 50-373/374

JUL 16 1985

Mr. Dennis L. Farrar
Director of Licensing
P.O. Box 767
Chicago, Illinois 60690

Dear Mr. Farrar:

SUBJECT: ACCEPTANCE OF CRITERIA FOR FIRECODE CT GYPSUM FIRE STOPS-
LA SALLE COUNTY STATION, UNITS 1 & 2

By letter dated May 28, 1985, you requested the staff's concurrence on use of certain revised acceptance criteria and separation based on newly obtained test data for Firecode CT Gypsum Fire Stops for La Salle county Station, Units 1 and 2.

Based on our review, we find that the tested seal configuration bounds the La Salle configuration and that the proposed criteria are acceptable. A copy of the related Safety Evaluation is enclosed.

Sincerely,

Walter R. Butler, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure: As stated

cc: See next page

Distribution:

Docket file	NRC PDR	Local PDR	PRC System	NSIC	LB#2Reading	EHylton
ABournia	OELD Woodhead	ACRS(16)	JPartlow	BGrimes	EJordan	
W.G. Guldemon, R. III						

LB#2/DL/LA
EHylton
7/15/85

LB#2/DL/PM
ABournia:mk
7/15/85

LB#2/DL/BC
WButler
7/15/85

W3

8507300199 850716
PDR ADOCK 05000373
F PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUL 16 1985

Docket Nos: 50-373/374

Mr. Dennis L. Farrar
Director of Licensing
P.O. Box 767
Chicago, Illinois 60690

Dear Mr. Farrar:

SUBJECT: ACCEPTANCE OF CRITERIA FOR FIRECODE CT GYPSUM FIRE STOPS-
LA SALLE COUNTY STATION, UNITS 1 & 2

By letter dated May 28, 1985, you requested the staff's concurrence on use of certain revised acceptance criteria and separations based on newly obtained test data for Firecode CT Gypsum Fire Stops for La Salle County Station, Units 1 and 2.

Based on our review, we find that the tested seal configuration bounds the La Salle configuration and that the proposed criteria are acceptable. A copy of the related Safety Evaluation is enclosed.

Sincerely,

A handwritten signature in cursive script, reading "Walter R. Butler".

Walter R. Butler, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure: As stated

Mr. Dennis L. Farrar
Commonwealth Edison Company

La Salle County Nuclear Power Station
Units 1 & 2

cc:

Philip P. Steptoe, Esquire
Suite 4200
One First National Plaza
Chicago, Illinois 60603

John W. McCaffrey
Chief, Public Utilities Division
160 North La Salle Street, Room 900
Chicago, Illinois 60601

Assistant Attorney General
188 West Randolph Street
Suite 2315
Chicago, Illinois 60601

Resident Inspector/LaSalle, NPS
U.S. Nuclear Regulatory Commission
Rural Route No. 1
Post Office Box 224
Marseilles, Illinois 61341

Chairman
La Salle County Board of Supervisors
La Salle County Courthouse
Ottawa, Illinois 61350

Attorney General
500 South 2nd Street
Springfield, Illinois 62701

Chairman
Illinois Commerce Commission
Leland Building
527 East Capitol Avenue
Springfield, Illinois 62706

Mr. Gary N. Wright, Manager
Nuclear Facility Safety
Illinois Department of Nuclear Safety
1035 Outer Park Drive, 5th Floor
Springfield, Illinois 62704

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137